

# Annual Drinking Water Quality Report

2023 - 2024



[www.lmw.vic.gov.au](http://www.lmw.vic.gov.au)



  
**LOWER MURRAY  
WATER**

  
**VICTORIA**  
State  
Government

# Acknowledgement of Country



*Artwork by Bella Sloane*

Lower Murray Water acknowledges the Traditional Owners of the land on which we work and reside. We recognise their continuing connection to land, waterways, and community. We pay our respects to Elder's past, present and future.

The Traditional Owner groups within Lower Murray Water's service region lie within the traditional lands of First Nations Peoples, from upstream at Koondrook moving downstream along the Murray River through to the western edge of our region at the South Australian border.

They are the Barapa Barapa Peoples, Wamba Wamba Peoples, Wadi Wadi Peoples, Tatti Tatti Peoples, Latji Latji Peoples, Nyeri Nyeri Peoples, Ngintait Peoples, and the Wergaia Peoples.

The First Nation Peoples' connection to land and water is the living cultural knowledge that is passed down from generation to generation. The stories that connected the ancestors to their culture still live through the First Nations Peoples of today.

- Acknowledgement of Country written by Stephanie Sloane.

Stephanie works at Lower Murray Water as the Diversity and Inclusion Officer. She is a proud Ngiyampaa woman and has a strong connection to her culture, history and the land. Stephanie has brought not only her experience and passion for people to this role but also a commitment to inspire and mentor others wishing to pursue a career at Lower Murray Water.

# Table of Contents

Acknowledgement of Country .....	2
Glossary of Terms .....	5
From our Managing Director .....	6
Our Service Region .....	7
Nature and Range of Services Provided .....	8
Water Supply Systems .....	8
TABLE 1 - LMW Water Supply Systems .....	9
Source water .....	9
Catchment Management.....	10
Drinking Water Treatment Processes .....	11
Figure 1. Drinking Water Treatment Processes.....	11
Coagulation and Flocculation .....	11
Sedimentation .....	12
Solid contact Clarification .....	12
Dissolved Air Flotation (DAF) .....	12
Filtration .....	12
Disinfection with Chlorine Gas .....	12
Ultraviolet (UV) disinfection .....	12
pH correction .....	13
Fluoridation .....	13
Powdered Activated Carbon (PAC).....	13
Manganese treatment .....	13
TABLE 2 - LMW Drinking Water Treatment Processes .....	13
Drinking Water Quality Management .....	14
Quality Management Systems .....	14
Verification of Water Quality Monitoring .....	14
Sampling Points .....	2
Tank Cleaning.....	2
Emergency incident and event management .....	2
Section 18 and 22 Notifications .....	2
Reportable Incidents 2023-24 .....	2
Issues .....	3
Three-year Percentage Compliance.....	3
Figure 2 - Compliance with Water Quality Standards .....	4
Fluoride Treatment.....	4
Fluoride outage notifications .....	5
Aesthetic Characteristics.....	5
Water quality and safety improvement initiatives.....	5

Staff Training .....	6
Drinking Water Quality Standards.....	6
Other Water Quality Standards .....	7
Blue-green Algae .....	7
Water Quality Complaints .....	9
2023/24 Complaints Data.....	9
Risk management plan audit results .....	11
Audit Process.....	11
Regulated water .....	15
What is Regulated Water? .....	15
LMW's Regulated Water Supplies.....	15

# Glossary of Terms

<b>The Act</b>	Safe Drinking Water Act 2003 (Vic)
<b>The Regulations</b>	Victorian Safe Drinking Water Regulations 2015
<b>ADWG</b>	Australian Drinking Water Guidelines 6, 2011. Published by the National Health and Medical Research Council of Australia, version 3.8, Updated September 2022.
<b>DH</b>	Victorian Department of Health
<b>EPA</b>	Environment Protection Authority
<b>ESC</b>	Essential Services Commission
<b>RMP</b>	Risk Management Plan
<b>DWQMP</b>	Drinking Water Quality Management Plan
<b>DWQMT</b>	Drinking Water Quality Management Team
<b>HACCP</b>	Hazard Analysis and Critical Control Points
<b>NATA</b>	National Association of Testing Authorities
<b>BGA</b>	Blue Green Algae are Cyanobacteria that can range in colour from yellow to purple. Some types can be highly toxic to humans, livestock, and birds.
<b>Coliforms Bacteria</b>	Widely distributed throughout the environment, which provide a sensitive measure of microbiological quality
<b>E. coli</b>	Escherichia coli, a type of pathogenic bacteria that normally lives in human intestines, which indicate the presence of faecal contamination and therefore, is a health risk
<b>THMs</b>	Trihalomethanes
<b>NTU</b>	Nephelometric turbidity units
<b>CFU/100mL</b>	Colony forming Units per 100 millilitres
<b>CFU/mL</b>	Colony Forming Units per millilitre
<b>mg/L</b>	Milligrams per litre
<b>RPZ</b>	Reduced Pressure Zone
<b>Water Sampling Locality</b>	An area that has common water quality characteristics because the supply is provided through specific pipes, tanks, or pumps. It is more likely to follow geographic features than suburb boundaries
<b>Water Hardness</b>	Refers to the concentration of calcium and magnesium salts in water, which can attach to surfaces and cause a hard, flaky scale. These salts can also make it difficult to achieve lather when using soap.
<b>UV Disinfection</b>	Ultraviolet disinfection

# From our Managing Director

I am pleased to present Lower Murray Urban and Rural Water Authority's (LMW) 2023/24 Annual Drinking Water Quality Report (ADWQ). It provides comprehensive information on the quality of drinking water we have provided to our customers and community throughout LMW's service area, which extends from Kerang to the South Australian border, in the municipalities of Gannawarra, Swan Hill and Mildura. The report highlights all the test results from our water quality monitoring program and outlines the processes we have in place to continue delivering safe, clean drinking water to all.

This report is provided to the Secretary to the Department of Health (DH) in accordance with section 26 of the Safe Drinking Water Act 2003 (the Act), and Regulations 16 and 17 of the Safe Drinking Water Regulations 2015 (the Regulations). This report includes a summary of the chemical, physical and bacteriological test results of drinking water supplied to our customers, as part of our water quality monitoring program for each water sampling locality.

The information presented in this report explains the sources of our drinking water and how it is treated to ensure it consistently meets regulatory requirement. It further demonstrates our commitment to delivering water of high-quality standards, and highlights water quality challenges experienced as well as our improvements in 2023/24.

In addition to the above, the report includes the following information:

- an overview of our water supply systems and sources of our water supply.
- a summary of water treatment and disinfection processes.
- an outline of how we arrange collection and testing of water samples.
- details of customer feedback regarding water quality and safety.

LMW is a statutory water authority created under the *Water Act 1989* and governed by a board of non-executive directors appointed by the Minister for Water. We work closely with the Environment Protection Authority (EPA), the DH and the Essential Services Commission (ESC), as they regulate and monitor the service performance of our environmental, public health, and water pricing obligations.

In accordance with the Act, we have adopted a multiple-barrier, catchment-to-tap approach to ensure safe, high-quality, drinking water is supplied to our customers. We are also required to prepare and implement a Drinking Water Quality Management Plan (DWQMP) to ensure the safety of our drinking water supply systems. Our DWQMP is based on Hazard Analysis and Critical Control Point (HACCP) principles and the Australian Drinking Water Guidelines 2011 (ADWG). The DWQMP was audited in March 2023 and LMW was compliant with 18 Opportunity for Improvement (OFI) noted.

We verify the quality of the drinking water through a comprehensive monitoring program that also allows us to identify potential improvements to benefit our customers and the community. We also rely upon feedback from customers to advise of local issues that may arise, which are treated as water quality complaints.

LMW is committed to continuing its record of reliably providing high quality, safe drinking water to our customers. I'm pleased to advise that we achieved full compliance with the water quality standards and requirements of the Act and Regulations.



Paul Northey  
Managing Director

# Our Service Region



Our area of operation extends from Kerang to the South Australian border taking in the municipalities of Mildura, Swan Hill and Gannawarra. We recognise that the overall wellbeing and livelihood of our communities' is directly linked to the agricultural, tourism and support industries which form our economic backbone. How we manage our water resources recognises the intrinsic interrelationship between this resource and the social, environmental, and economic fabric of our region.

# Nature and Range of Services Provided

LMW provides services to rural and urban customers including:

- Urban water services to 14 townships via nine treatment plants to 34,784 households and businesses and approximately 76,000 customers along the Murray River from Koondrook to Merbein.
- Wastewater collection, treatment and effluent re-use and disposal services to 11 towns via 10 treatment plants.
- Raw (river quality) water services to 2,666 irrigation and 2,240 stock and domestic customers in the four pumped irrigation districts of Mildura, Merbein, Red Cliffs and Robinvale, and to 297 Millewa waterworks district customers and 12 Yelta waterworks district customers.
- Management of the region's urban and rural bulk water entitlements.
- The collection and disposal of subsurface drainage water from the four pumped irrigation districts, as well as from private diverters in Nangiloc, Robinvale, and Boundary Bend.
- Oversight of irrigation and drainage design in new agricultural developments ensuring conformity with salinity management plan development guidelines.
- Management of the private diversion licenses of 1,313 water users along the Murray River in Victoria between Nyah and the South Australian border.
- The assessment and approval of licensing, water share and allocation trade applications.
- Reclaimed water for third party use.
- Water supply delivery to important environmental and recreational sites.
- Lead agency in a partnership model for the Victorian Murray Floodplain Restoration Project.

In addition to security of supply, public health, water quality and environmental responsibilities, LMW recognise the crucial economic role of water from a regional and state context.

## Water Supply Systems

LMW manages eight drinking water supply systems, which provide drinking water to a population of approximately 76,590 customers along the Murray River in Victoria from Kerang to Merbein. LMW also has two regulated water supplies, including Millewa and Mystic Park. A water quality improvement plant operates at Millewa to improve water quality for domestic and stock uses, but not for drinking.

Regulated water is not drinking water but could be mistaken for drinking water and is discussed in more detail in the Regulated Water section of this report.

Details of our drinking water and regulated water supply systems, including water sampling localities, population supplied, source water and Water Treatment Plants (WTP) are provided in Table 1. We do not manage raw water storages for drinking water supplies as we draw directly from the Murray River or other smaller waterbodies.

The population figures have been calculated based on the number of water connections as of 30 June 2024 (31,541) multiplied by the 2021 Census average household population for each region. Non-residential connections are not included. Locations of drinking water supply systems are shown on the map of our service region.

This report, in accordance with the Act, provides an overview of our drinking water supply systems, the quality systems in place for provision of safe drinking water and the drinking water test results for 2023/24.



**TABLE 1 - LMW Water Supply Systems**

Water Sampling Locality	Population	Source Water	Treatment Plant
Irymple	8,502	Murray River	Mildura 7th street and Mildura West
Kerang	4,103	Murray River 14/2 Irrigation Channel	Kerang
Koondrook	1,078	Murray River	Koondrook
Lake Boga	1,153	Murray River	Swan Hill
Merbein	3,645	Murray River	Mildura 7th street Mildura West
Mildura	37,229	Murray River	Mildura 7th street Mildura West
Murrabit	104	Murray River Storage Dam	Murrabit
Nyah	649	Murray River	Swan Hill
Nyah West	607	Murray River	Swan Hill
Piangil	265	Murray River	Piangil
Red Cliffs	4,145	Murray River	Red Cliffs
Robinvale	2,422	Murray River	Robinvale
Swan Hill	12,264	Murray River	Swan Hill
Woorinen South	427	Murray River	Swan Hill
Millewa*	297	Lake Cullulleraine	Millewa Water Quality Improvement Plant
Mystic Park*	28	Kangaroo Lake	N/A
	Total: 76,918		

\* Regulated Supplies

## Source water

The source of water for most of the drinking water supplies in our service region is the Murray River. Two exceptions to this are the Kerang and Murrabit drinking water supplies. The Kerang supply system sources its water from the GMW 14/2 Irrigation Channel in addition to the Murray River. The Murrabit drinking water supply source its water either from the Murray River or from a storage dam at the plant, which is supplied from the GMW channel, during times of BGA blooms along the Murray River.

LMW's regulated water supplies source water from Kangaroo Lake and Lake Cullulleraine (although this is directly connected to the Murray River) for the Mystic Park and Millewa areas respectively.

The Murray River catchment (part of the Murray-Darling Basin) covers a large area that spans Victoria, New South Wales, and Queensland. Water from Queensland catchments enter the Murray River downstream of Mildura so does not impact on our WTPs' raw water offtakes. Several other water agencies located upstream of our offtakes also utilise the Murray River to provide drinking water to major towns along the Murray River including Albury, Wodonga, Cobram, Echuca, and other smaller localities.

In 2015, we carried out a sanitary survey to identify the intensity and sources of contamination of water sources within the catchment area of our service region. The results indicated that the Murray River catchment is subject to various activities, which impact on water quality. Murray River lies within an open and unprotected catchment, where various activities such as stock grazing, human habitation, agriculture, and industry, take place. Dominant agricultural activities include extensive horticultural areas, the

production of almond, olive, dairy, wool, wheat, beef, lamb, and forestry. An abundance of recreational activities is undertaken along the Murray River and its tributaries including camping, swimming, fishing, water skiing, canoeing, sightseeing, and picnicking.

As a result, Murray River water is subject to a high microbial and chemical risk from humans, stock, and industry. To assess that LMW's water treatment processes can manage these risks, we have a source water quality monitoring program, which involves collecting and testing of source water samples for a range of parameters such as turbidity, colour, UV absorbance, pesticides, radioactivity, etc. to help assess risks from the catchment. In addition, the raw water turbidity is monitored online at all WTPs, which provides an early warning to treatment plant operators of potential changes to the raw water quality. This enables operators to undertake control measures to ensure adequate treatment is applied to the raw water and potential for process deviation is reduced.

To quantify the microbial risks in the catchment and realising the similarities in each catchment and the microbial hazards, we conducted a detailed microbial hazard quantification assessment on our drinking water supply systems. The assessment used the methodology outlined in the Australian Drinking Water Guidelines (ADWG) and the Water Services Association Australia (WSAA) Manual for the Application of Health Based Targets for Drinking Water (2015). We undertook a review of the QMRA done in 2015 to update the current state of knowledge and identify any potential gaps that might exist with the inclusion of the HBT targets in the ADWG released in 2022.

LMW has been monitoring *Cryptosporidium* and *Giardia* in the source water since January 1998. The monitoring frequency has changed to fortnightly and includes *E. coli*, to enable ongoing quantification and assessment of the source water risks.

LMW conducts seasonal monitoring of Blue Green Algae (BGA) to detect any potential presence of BGA. When any blooms are detected, appropriate and robust control measures are employed to the treatment process to ensure that water is safe for drinking and compliant with ADWG guidelines. Frequency of BGA monitoring is weekly which can be increased conditional to the levels of BGA identified in source water.

## Catchment Management

LMW always endeavours to reduce potential risks to water quality in the Murray River being the main source of water supply for our water supply systems.

LMW is an active partner in the state-wide program that collects water and groundwater data, called the Regional Water Monitoring Partnership managed by Department of Energy, Environment and Climate Action (DEECA). LMW work closely with Mallee Catchment Management Authority (CMA) to assess the risks of chemical contaminants in irrigation drainage water. We are a participating member of the Mallee CMA's Mallee floodplain management strategy implementation committee. This committee seeks to understand flooding risks for our region and coordinate a response to these risks with multiple agencies via development and implementation of mitigating actions.

Actions to date include mapping floodplains to help understand future flood risks and the building of strategically placed levees. LMW is a member of the Mallee CMA's Regional Catchment Steering committee which is in the process of renewing the Regional Catchment Strategy, a document which underpins the sustainable management of land and water resources and contributes to biodiversity management.

LMW regularly partners with Mallee CMA to flush Psyche bend lagoon on a high river, to reduce the salt load in the lagoon using LMW infrastructure. While this sounds counterproductive to water quality, this activity prevents highly saline waters to enter the river when a rain event occurs during a low river, which can trigger an electroconductivity exceedance in Morgan SA, and compromises water quality for LMW offtakes downstream. By doing this on a high river, the salinity is effectively diluted and poses no problems for water quality downstream of the lagoon.

# Drinking Water Treatment Processes

During 2023/24, LMW treated more than 20,000 megalitres (ML) of drinking water across nine WTPs. All these WTPs use conventional water treatment systems, with one WTP utilising dissolved air flotation as part of its treatment system. The water treatment systems involve the following process steps:


- coagulation
- flocculation
- clarification/sedimentation/Dissolved Air Flotation
- filtration
- chlorine Disinfection
- fluoridation
- pH correction
- UV disinfection

Our drinking water is disinfected using chlorine, the most widely used disinfectant in the water industry. Chlorine dose rates are adjusted to provide adequate free chlorine residual throughout the distribution system. This helps provide some protection against potential contamination within the reticulation system and can limit biological regrowth. LMW has recently completed the UV project to retrofit all nine drinking WTPs with UV disinfection systems, which provides the additional barrier for Protozoa in line with the ADWG recommendations and industry best practice.

Water treatment processes may slightly differ from one WTP to another due to plant capacity, technology type or raw water quality characteristics of source water. Steps in the drinking water treatment process are outlined in Figure 1.

Table 2 shows water sampling localities, WTPs that supply water to those localities, treatment processes used to treat the water per locality, and chemicals used for water treatment.

Figure 1. Drinking Water Treatment Processes



## Coagulation and Flocculation

The first step of the conventional treatment process involves dosing a chemical coagulant to help gather suspended solids and organic material in the raw water. We use aluminium sulphate or aluminium chlorohydrate to bring about the coagulation process, which helps form larger particles called 'flocs' that can be more readily removed by subsequent treatment steps. During flocculation, the floc particles develop and agglomerate into larger particles. The larger size and weight of the agglomerated particles assists in the sedimentation or clarification process. Flocculant aids including polyelectrolytes are also commonly

used to enhance the flocculation phase, which further assists in the sedimentation and clarification processes.

## Sedimentation

Sedimentation is a step in the treatment process intended to enhance the filtration process, where suspended particles are removed from the water by means of gravity or separation. In the sedimentation process, the water passes through a relatively quiet and still basin. In these conditions, the floc particles settle to the bottom of the basin while 'clear' water passes out of the basin over an effluent baffle or weir. The solids collected on the bottom of the basin are removed through sludge bleeding pipework at the smaller "package" WTPs, or by a mechanical 'sludge collection' device at the larger plants, which scrapes the solids (sludge) to a collection point within the basin from which it is pumped to a storage for further treatment and disposal.

## Solid contact Clarification

The purpose of the solid contact clarification is the same as the sedimentation process, i.e., to enhance the filtration process by removing particles. It involves mixing the influent flow with previously settled solids within a cylinder located in the centre of the clarifier. Gentle mixing within the reaction well promotes agglomeration of floc particles and/or chemical precipitates. The aggregated solids settle out more rapidly in the clarification area. Even better clarity is achieved when particles become enmeshed in a sludge blanket layer. Rotating sludge scrapers transport settled solids to the centre of the basin for removal. Clarified overflow is removed through a circular launder system that draws water from the entire surface area to prevent solids carryover caused by uneven velocity currents.

## Dissolved Air Flotation (DAF)

The process of flotation consists of three steps:

- bubble formation
- attachment of bubbles to the solids
- solids separation from the fluid

In DAF systems, air is pressurised under several atmospheres and then introduced into water, where it is mixed with pre-coagulated water just before it enters the flotation tank.

Upon attachment of air bubbles to the solid particles, the density of the solid becomes less than that of the surrounding fluid. In the process, the buoyant force lifts the solids to the surface to form a scum blanket, which is continuously swept to the periphery, automatically discharged into a scum trough by the skimming device.

## Filtration

Filtration occurs as the water passes through filters that help remove particles that have not settled in the sedimentation process. Filters are commonly used in the water treatment process and may contain layers of gravels, sands and filter coal. The filtration process removes fine suspended solid matter as well as some other particles including larger micro-organisms, resulting in clear water passing through.

## Disinfection with Chlorine Gas

Water is disinfected to kill any pathogens (disease-causing organisms) that remain in the treated water after filtration and provide protection within the distribution system. Without disinfection, the risk from waterborne disease is greatly increased. Disinfection is carried out by chlorination at all our WTPs in the form of chlorine gas.

## Ultraviolet (UV) disinfection

UV disinfection is widely used in water treatment due to its ability to permanently de-activate bacteria, spores, moulds and viruses. It provides a secondary barrier to the conventional water treatment process, where filtration is the only barrier against protozoan pathogens, such as *Cryptosporidium* and *Giardia*. UV

disinfection is highly effective against the *Cryptosporidium* oocysts and *Giardia* cysts that are resistant to the routinely applied doses of chlorine.

## pH correction

Due to the addition of coagulants and chlorine, the pH of the water being treated is lowered, becoming more acidic. To inhibit corrosion and make the water safe to use, the pH is adjusted to a neutral pH, about pH 7.0, by adding lime or other alkaline chemicals such as soda ash or sodium hydroxide.

## Fluoridation

Water fluoridation is the adjustment of fluoride in drinking water to a level that helps protect teeth against dental decay. We fluoridate five water supply systems that deliver fluoridated water to 12 localities within our service region. Fluoridation of the drinking water supplies is undertaken as per the requirements of the Health (Fluoridation) Act 1973.

## Powdered Activated Carbon (PAC)

PAC is derived from a variety of sources such as coal, wood, and coconut. Due to its high adsorption capacity, i.e., ability to attract contaminants and bind them to its surface, PAC is used to assist in removing taste & odour compounds, blue-green algae toxins, and other impurities from water.

## Manganese treatment

We use Calgon-T for manganese treatment, which is a sequestering agent that prevents the oxidation of manganese in the treated water and eliminates water discolouration.

**TABLE 2 - LMW Drinking Water Treatment Processes**

Water Treatment Plant	Water Supply Locality	Treatment Process	Added Substances
<b>Kerang</b>	Kerang	<ul style="list-style-type: none"> <li>- Coagulation</li> <li>- Flocculation</li> <li>- Sedimentation</li> <li>- Granular Media Filtration</li> <li>- Chlorine Disinfection</li> <li>- Fluoridation</li> <li>- UV Disinfection</li> </ul>	<ul style="list-style-type: none"> <li>- Aluminium Sulphate</li> <li>- Hydrated Lime</li> <li>- Sodium Hydroxide</li> <li>- Chlorine Gas</li> <li>- Powdered Activated Carbon</li> <li>- Fluorosilicic Acid</li> <li>- Calgon T</li> </ul>
<b>Koondrook</b>	Koondrook	<ul style="list-style-type: none"> <li>- Coagulation</li> <li>- Flocculation</li> <li>- Sedimentation</li> <li>- Granular Media Filtration</li> <li>- Chlorination</li> <li>- UV Disinfection</li> </ul>	<ul style="list-style-type: none"> <li>- Aluminium Sulphate</li> <li>- Sodium Hydroxide</li> <li>- Chlorine Gas</li> <li>- Powdered Activated Carbon</li> <li>- Calgon T</li> </ul>
<b>Mildura 7th Street Mildura West<sup>1</sup></b>	Mildura Merbein Irymple	<ul style="list-style-type: none"> <li>- Coagulation</li> <li>- Flocculation</li> <li>- Sedimentation</li> <li>- Clarification<sup>2</sup></li> <li>- Slow Sand Filtration</li> <li>- Chlorination</li> <li>- Fluoridation</li> </ul>	<ul style="list-style-type: none"> <li>- Aluminium Sulphate<sup>2,3</sup></li> <li>- Aluminium Chlorohydrate<sup>3</sup></li> <li>- Hydrated Lime<sup>2</sup></li> <li>- Polymer</li> <li>- Chlorine Gas</li> <li>- Powdered Activated Carbon</li> <li>- Fluorosilicic Acid</li> <li>- Sodium Metabisulfite<sup>3</sup></li> <li>- Sodium Hydroxide<sup>3</sup></li> <li>- Calgon T</li> </ul>
<b>Murrabit</b>	Murrabit	<ul style="list-style-type: none"> <li>- Coagulation</li> <li>- Flocculation</li> <li>- Sedimentation</li> </ul>	<ul style="list-style-type: none"> <li>- Aluminium Chlorohydrate</li> <li>- Sodium Hydroxide</li> <li>- Chlorine Gas</li> </ul>

<sup>1</sup> Mildura West and Red Cliffs can utilise either Aluminium Sulphate or Aluminium Chlorohydrate. This flexibility is desired in periods of chemical supply shortages or also based on raw water quality

<sup>2</sup> Applies to Mildura 7th Street WTP only

<sup>3</sup> Applies to Mildura West WTP only

		<ul style="list-style-type: none"> <li>- Granular Media Filtration</li> <li>- Chlorination</li> <li>- UV Disinfection</li> </ul>	<ul style="list-style-type: none"> <li>- Powdered Activated Carbon</li> <li>- Calgon T</li> </ul>
<b>Piangil</b>	Piangil	<ul style="list-style-type: none"> <li>- Coagulation</li> <li>- Flocculation</li> <li>- Sedimentation</li> <li>- Granular Media Filtration</li> <li>- Chlorination</li> <li>- UV Disinfection</li> </ul>	<ul style="list-style-type: none"> <li>- Aluminium Chlorohydrate</li> <li>- Sodium Hydroxide</li> <li>- Chlorine Gas</li> <li>- Powdered Activated Carbon</li> <li>- Calgon T</li> </ul>
<b>Red Cliffs<sup>1</sup></b>	Red Cliffs	<ul style="list-style-type: none"> <li>- Coagulation</li> <li>- Flocculation</li> <li>- Pre-sedimentation</li> <li>- Dissolved Air Flotation</li> <li>- Granular Media Filtration</li> <li>- Chlorination</li> <li>- Fluoridation</li> <li>- UV Disinfection</li> </ul>	<ul style="list-style-type: none"> <li>- Aluminium Chlorohydrate</li> <li>- Aluminium Sulphate</li> <li>- Sodium Hydroxide</li> <li>- Chlorine Gas</li> <li>- Powdered Activated Carbon</li> <li>- Fluorosilicic Acid</li> <li>- Calgon T</li> </ul>
<b>Robinvale</b>	Robinvale	<ul style="list-style-type: none"> <li>- Coagulation</li> <li>- Flocculation</li> <li>- Clarification</li> <li>- Granular Media Filtration</li> <li>- Chlorination</li> <li>- Fluoridation</li> <li>- UV Disinfection</li> </ul>	<ul style="list-style-type: none"> <li>- Aluminium Sulphate</li> <li>- Soda Ash</li> <li>- Chlorine Gas</li> <li>- Powdered Activated Carbon</li> <li>- Sodium Fluoride</li> <li>- Polymer</li> <li>- Calgon T</li> </ul>
<b>Swan Hill</b>	Swan Hill	<ul style="list-style-type: none"> <li>- Coagulation</li> <li>- Flocculation</li> <li>- Clarification</li> <li>- Slow Sand Filtration</li> <li>- Chlorination</li> <li>- Fluoridation</li> </ul>	<ul style="list-style-type: none"> <li>- Aluminium Chlorohydrate</li> <li>- Sodium Hydroxide</li> <li>- Chlorine Gas</li> <li>- Powdered Activated Carbon</li> <li>- Fluorosilicic Acid</li> <li>- Calgon T</li> </ul>

## Drinking Water Quality Management

### Quality Management Systems

LMW's DWQMP has been developed based on the 12 elements of the 'Framework for Management of Drinking Water Quality', described in the Guidelines and the requirements set out in the Act. The plan identifies key water quality risks in the water supply system using a catchment to tap approach. Each key risk is assessed, and critical control points are put in place to manage those risks to provide safe drinking water to our customers.

### Verification of Water Quality Monitoring

Water quality monitoring constitutes a significant part of our water supply activities. We have a water quality monitoring program that was designed based on the requirements of the Regulations, and the Guidelines, including consideration of locality population numbers for bacterial monitoring.

Using the outcomes of the sanitary survey to assist in identifying the source water quality hazards and risks, we reviewed the irrigation practices within our catchment area to identify raw water quality parameters that potentially constitute health risks, and therefore, require ongoing monitoring.

The Guidelines provide a basis for assessing the quality of drinking water. The microbiological assessment is based on E. coli, which is considered a definitive indicator for the presence of faecal contamination, and therefore, a health risk. In terms of the physical and chemical monitoring, it is based on a combination of parameters that indicate the physical and aesthetic characteristics of water such as pH, colour and turbidity, as well as the chemical quality of the water, which include but not limited to free chlorine, iron and manganese, fluoride, dissolved salts, aluminium, copper, lead, chromium, nickel, and other parameters.

To comply with the water quality monitoring requirements set out in the Act and Regulations, we use an external National Association of Testing Authorities (NATA) registered laboratory to perform all regulatory

drinking water testing, which was developed based on a rigorous risk assessment process. All drinking water quality test results for 2023/24 are available in Appendix A.

In 2023/24 we collected around 3,900 samples from 16 water supply localities and analysed these for more than 40 parameters to assess water quality and safety.

## Sampling Points

The water quality sampling points have been carefully chosen based on the DH 'Water Monitoring Program guidance', and risk assessment approach with the objective of identifying effective strategies for prevention and control of hazards within the distribution system.

This involved understanding the characteristics of the drinking water system, what hazards may arise, how these hazards create risks, and the processes and practices that affect drinking water quality.

While the sampling points are representative of the water quality within their subsequent supply systems, a regular review of the sampling points is undertaken to verify the locations of the current sampling points, ensure that they reflect the associated water quality risks within their distribution systems, and assess the need to add in additional sampling points to reflect the expansion of the water supply localities that results from population growth, i.e., new subdivisions.

## Tank Cleaning

A scheduled inspection and maintenance program is in place for cleaning clear water storage tanks and service reservoirs, which was followed in 2023/24. This involved general inspections of the interior and exterior of the storages for sediment build-up, asset condition, and the roof area to ensure that access hatches are properly sealed and prevent contamination that could result from rainwater ingress, and desludging of water storages as required.

In addition to physical inspections of clear water storages and service reservoirs, we recently undertook an extensive drone inspection for water tank condition inspections for all LMW storages. Based on the drone and diver inspection reports a list was compiled and prioritisation of the works have been completed.

# Emergency incident and event management

## Section 18 and 22 Notifications

Section 22 of the Act requires an officer of a water supplier to notify the DH where it's suspected that the drinking water supplied, or to be supplied to customers, may pose a risk to human health, or cause widespread public complaint. LMW reported two instances of known or suspected contamination as required under Section 22 of the Act.

Section 18 of the Act require water suppliers to notify the Secretary of DH if it becomes aware that the drinking water supplied, or to be supplied, to another person does not comply, or is not likely to comply, with any relevant water quality standard and must do so within 10 days after it becomes aware of that fact. There were no incidents that required reporting under Section 18 of the Act.

## Reportable Incidents 2023-24

During 2023/24 the drinking water supplied to our customers was of high standard, except as described below.

A range of organisms that grow naturally in water bodies can produce substances that can create unpleasant tastes and odours (T&O) in drinking water supplies. The most common of these substances are Geosmin and 2-Methylisoborneol (MIB). While these substances create unpleasant T&Os in drinking water, they do not pose a risk to public health. A section 22 notification was submitted to DH in February 2024 for potential widespread public complaints in the Kerang water supply locality due to elevated concentration of T&O compounds in the treated water. Given that the concentration of MIB in the raw water was extremely high, the concentration of MIB in the treated drinking water exceeded the T&O threshold of 10 ng/L, which

is mentioned in the ADWG. LMW received 21 taste and odour complaints. Portable water was carted from Swan Hill WTP to Kerang to provide customers water for cooking and drinking.

A Section 22 notification was submitted to DH in March 2024 in response to a break in at the 10<sup>th</sup> Street elevated storage in Mildura Water Sampling Locality. Inspection of the elevated storage did not find any evidence of chemical, or liquid was introduced into the storage. Based on a rapid risk assessment, the risk to human health was considered low. Samples were collected from the storage and customer taps which did not indicate any contamination. LMW did not receive any customer complaints for illness or water quality.

## Issues

Non-compliance with Regulation 14, which is the requirement for samples collected as part of the sampling program to be analysed.

The following issue relates to the water quality monitoring schedule that occurred in financial year 2023/24.

The regulatory sample collected on 2 April 2024 from 574C04 (Woorinen South) in Woorinen South water sampling locality was sent to the ALS laboratory in Melbourne. The laboratory lost the sample bottle required for chemistry tests (pH, turbidity, fluoride and true colour). All other testing (micro, HAA, THM and metals) on this network sample was completed. The sample bottle was received by the ALS sample receipt team on 3 April 2024, however due to a suspected barcode scanning issue, when the sample was scanned to be receipted into ALS's Laboratory Information Management System, the container was not allocated a storage location id, which allows the lab staff to find and track the sample. This was not noticed until a later date when the staff were looking for the sample for received containers. There were no critical point activations at the Swan Hill water treatment plant on 2 April 2024. The average chlorine residual post treated water storage was 1.33 mg/L. The 95<sup>th</sup> percentile for filtered water turbidity was < 0.15 NTU. There was no detection of *E. coli* in the sample collected from 574C04 or any other samples collected in the network on the same day.

**Table 2 – Missing water quality parameter**

Date Sampled	Source of Sample	Testing Frequency	Water Quality Test Parameters	Locality
2 April 2024	Reticulation	Weekly	pH, turbidity, fluoride and true colour	Woorinen South

## Three-year Percentage Compliance

A comparison of test results of water samples collected in accordance with the sampling program set out in our DWQMP, and percentage of complying samples over the last three financial years, based on the regulated parameters stipulated in the Regulations, was undertaken.


The high quality of the drinking water we supplied continued for 2023/24, complying fully with all water quality standards.

Figure 2 demonstrates the continued outstanding performance and achievement of full compliance with the water quality standards detailed in Schedule 2 of the Regulations.

Further detailed comparisons of water quality parameters with the previous two financial years are provided in the drinking water quality test results in Appendix A.



Figure 2 - Compliance with Water Quality Standards




### Fluoride Treatment

Levels of fluoride have remained consistently below the maximums specified in the ADWG over the three-year period.

During the reporting period, the rolling annual fluoride concentration of drinking water was within the operating range of 0.7 to 0.9mg/l, as recommended by DH to provide a dental health benefit which was achieved within all water supply systems.

Figure 3 – Annual average fluoride concentration in drinking water



LMW's water quality sampling program indicates that all localities that receive fluoridated water supply were compliant for fluoride for the reporting period. Comprehensive data is provided in Table 3 of Appendix A.

## Fluoride outage notifications

LMW notified DH of a total of three fluoride interruptions, where fluoride concentration in drinking water supplied was less than 0.6 mg/L for a continuous period of > 72 hours, as required under the Code of Practice for Fluoridation of Drinking Water Supplies (Vic).

These occasions occurred when fluoridation was taken offline as a precautionary measure while LMW undertook maintenance. A summary of interruptions is provided in Table 3.

## Aesthetic Characteristics

LMW's water quality sampling program included aesthetic drinking water parameters turbidity, salinity, hardness, pH and colour. These results are reported in detail in Appendix A.

**TABLE 3 – Summary of Fluoride Interruption**

Fluoridation Plant	Interruption Date	Resumption Date	Summary	Number of Days Fluoride is Off-line
<b>Kerang</b>	11/09/2024	27/09/2024	The fluoride dosing system was offline due to the replacement of the transfer pipe project.	18
<b>Swan Hill</b>	30/10/23	09/11/2023	The fluoride dosing was offline due to relocation of the dosing point as part of the UV upgrade project.	11
<b>Mildura 7<sup>th</sup> St</b>	4/04/2024	07/04/2024	Due to supply chain issue, there was delay in receiving the chemical.	3

## Water quality and safety improvement initiatives

During the 2023/2024 financial year, LMW completed or continued several projects that contribute to maintaining and improving the robustness of the water treatment process and ensuring that water quality and safety were not compromised.

After a successful installation and commissioning of UV disinfection systems at Red Cliffs, Piangil, Koondrook, Kerang, Robinvale, Mildura West and Murrabit WTPs from 2019 onwards, LMW continues its endeavour to improve the robustness of the water supply systems. This includes completing our project to retrofit the Mildura 7th Street and Swan Hill WTPs with UV disinfection systems.

UV disinfection systems provide a secondary barrier for pathogenic bacteria such as Cryptosporidium and Giardia, reduce risks to water safety especially during poor raw water quality events such as blackwater and blue-green algae blooms, and ensure the delivery of safe drinking water during such events.

Table 4 below lists the water quality and safety improvement projects that were initiated or completed in 2023/24.

**Table 4 – Water quality and safety improvement projects**

Water Treatment Plant (WTP)	Project	Project Status (Completed, In Progress, Planning)	Expenditure, \$ Actual FY2024
ALL SITES	Instrument Replacement	In Progress	\$98,457.66
Kerang WTP	UV Treatment Upgrade	Completed	\$307,083.60
Swan Hill WTP	UV Treatment Upgrade	Completed	\$2,171,398.00
Robinvale WTP	UV Treatment Upgrade	Completed	\$383,084.00
Mildura West WTP	UV Treatment Upgrade	Completed	\$560,145.05
Mildura 7th St WTP	UV Treatment Upgrade	Completed	\$2,838,594.55
Robinvale WTP	Fluoride Upgrade	In Progress	\$491.00
Mildura 7th St WTP	Fluoride Upgrade	In Progress	\$2,630.00
Kerang WTP	KER - WTP Filter Media Replacement	Completed	\$38,901.00
Mildura	MDA - Reline 10th St Tower Drain Line	Completed	\$19,997.00
Swan Hill WTP	SH - PAC pump upgrade SH WTP	Completed	\$11,227.00
Kerang	KER - RWP replacement KDK dry well	In Progress	\$1,128.00
Kerang	KER – Main Replacement Victoria St Btw Scoresby & Wellington Install 250m of DN150	In Progress	\$127,706.00
Kerang	KER - Tate Dr CWS Cathodic Protection Up	Completed	\$7,430.00

## Staff Training

LMW always endeavour to ensure that treatment plants’ operators have achieved Certificate III qualifications in water industry operations. Whilst some operators have already completed this training, others are progressing towards achieving Certificate III, and new members who have recently joined the operational team have been enrolled in this training program.

In addition, LMW’s treatment plant operators attend the Water Industry Operators Association (WIOA) conference in Bendigo on annual basis and visit other water authorities WTPs when the opportunity arises. In this reporting period, two of LMW’s treatment plant operators attended WIOA Network Operator Development Program to network and share the knowledge gained through their practical experience. We also engage instruments suppliers to conduct training on the operation and maintenance of the instruments.

## Drinking Water Quality Standards

During 2023/24 financial year, LMW remained 100% compliant with the water quality standards specified for drinking water in Schedule 2 of the Regulations. These are outlined in Table 5. All drinking water quality results can be found in Appendix A of this report.

**TABLE 5 - Schedule 2 Safe Drinking Water Regulations 2015 Drinking Water Quality Standards**

Parameter	Sampling Frequency	Quality Standards
<b>Escherichia coli</b>	One sample per week	No E. coli per 100 millilitres of drinking water, with the exception of any false positive sample.

<b>Total Trihalomethanes</b>	One sample per month	Less than or equal to 0.25 mg/l of drinking water.
<b>Turbidity</b>	One sample per week	The 95th percentile of results for samples in any 12-month period must be $\leq$ to 5.0 NTU.

## Other Water Quality Standards

In addition to the water quality parameters stipulated in the Regulations, we also monitored a range of other parameters, such as substances that may pose a risk to human health, to compare against ADWG health-related guideline values and ensure the safety and quality of the drinking water.

Table 6 lists other parameters included in the water quality parameters list, that are regularly monitored in drinking water samples collected from the reticulation system and water storages.

LMW has assessed the test results of these parameters against the ADWG health-related guideline values and found all results were fully compliant.

## Blue-green Algae

Blue-green algae (Cyanobacteria) are microscopic organisms that may thrive in warm, nutrient rich waters. They may impact water quality by releasing taste and odour compounds. In some extreme circumstances, these organisms may release concentrations of toxins.

As part of our water quality monitoring program, raw water samples are collected on a weekly basis from source water during the BGA season (November to May inclusive) and tested in-house for BGA cell count.

The BGA monitoring frequency increases to twice weekly if:

- $2,000 \leq \text{Cell Numbers} < 6,500$  Cells/mL *Microcystis aeruginosa*, or
- $0.2 \leq \text{Total Biovolume} < 0.6$  mm<sup>3</sup>/L

BGA blooms in drinking water supplies that may pose a risk to public health or may result in widespread public complaint, for example through taste and odour issues, must be notified to the DH using the notification arrangements under Section 22 of the Act.

Water supplied for drinking may place public health at risk due to one or more of the following:

- Total microcystins are detected at  $\geq 1.3$  µg/l (Microcystin-LR toxicity equivalents).
  - *Microcystis aeruginosa* is present at  $\geq 6,500$  cells/mL
  - Total combined biovolume of known toxic cyanobacterial species  $\geq 0.6$  mm<sup>3</sup>/L
  - Total combined biovolume of all cyanobacterial species  $\geq 10$  mm<sup>3</sup>/L
- or
- BGA is present in drinking water at levels that may cause widespread public complaint, for example through taste and odour.

**TABLE 6 – Other drinking water quality standards**

Parameter	ADWG 2011 Guideline (mg/L)		Frequency of testing	Met the guideline Yes/No
	Health	Aesthetic		
<b>Arsenic</b>	0.01		Quarterly	Yes
<b>Cadmium</b>	0.002		Quarterly	Yes
<b>Chlorine</b>	5	0.6	Weekly	Yes
<b>Chromium</b>	0.05		Quarterly	Yes
<b>Copper</b>	2	1	Quarterly	Yes
<b>Cyanide</b>	0.08		Quarterly	Yes
<b>Fluoride</b>	1.5		Weekly	Yes
<b>Lead</b>	0.01		Quarterly	Yes
<b>Manganese</b>	0.5	0.1	Quarterly	Yes
<b>Mercury</b>	0.001		Quarterly	Yes
<b>Nitrate</b>	50		Quarterly	Yes
<b>Iron</b>	c	0.3	Quarterly	Yes
<b>Zinc</b>	c	3	Quarterly	Yes
<b>Selenium</b>	0.01		Quarterly	Yes
<b>Nickel</b>	0.02		Quarterly	Yes
<b>Sulphate</b>	c	250	Quarterly	Yes
<b>Atrazine</b>	0.02		Yearly	Yes
<b>Chlorpyrifos</b>	0.01		Yearly	Yes
<b>Chlorothalonil</b>	0.05		Yearly	Yes
<b>Glyphosate</b>	1		Yearly	Yes
<b>Maldison (Malathion)</b>	0.07		Yearly	Yes
<b>Simazine</b>	0.02		Yearly	Yes
<b>Gross Alpha</b>			Every 5 years	Yes
<b>Gross Beta</b>			Every 5 years	Yes

c ADWG 2011 note that there is insufficient data to set a guideline value based on health conditions

# Water Quality Complaints

LMW is committed to providing high quality, safe drinking water and continuously improving services and communications to all customers. To ensure water quality complaints are resolved in appropriate timeframes, complaints are captured in LMW's customer management system 'MERIT', which provides workflow tracking of each complaint from registration to completion. MERIT directs the complaint to the relevant action officer to follow up with the customer. Complaints received after hours via our 1800 phone number are also directed to the relevant officer the next working day for follow up, if necessary.

If the issue cannot be resolved over the phone, an officer attends the property of concern to discuss the complaint with the customer, undertakes basic water quality testing such as pH, turbidity and colour, and takes water samples for taste tasting. Main's flushing will be undertaken, if necessary.

Monthly complaint summary reports for Board meetings, and quarterly reports for Essential Services Commission reporting are prepared from the MERIT database.

## 2023/24 Complaints Data

A total of 128 water quality complaints from a customer base of 76,918 equivalent to 0.166 complaints per 100 customers was recorded in 2023/24. This is a noticeable increase from 2022/23 where 79 water quality complaints were recorded, which equates to 0.104 water quality complaints per 100 customers.

Over the reporting period, the main water quality complaint was for discoloured water (62 complaints). Discoloured water can be attributed to one or a combination of several factors which could include a burst water main within the area, change in the direction of water flow that could result in scouring of the water mains, manganese, iron or potentially from a customer's internal plumbing or hot water service. The colour complaints account for 65% of the total number of complaints received throughout the reporting period.

LMW systematically undertake mains cleaning programs that assist in maintaining and improving water quality, consequently reducing the number of water quality complaints. Reactive mains flushing is conducted in response to customer requests to investigate water quality issues associated with colour, taste and/or odour complaints.

We monitor algae during the spring and summer season, where algae growth is accelerated due to the warm weather conditions. In general, we promote biological growth within the filter media, as it helps break down the taste and odour compounds. During algal blooms, we undertake additional treatment measures involving dosing of PAC at WTPs to help remove T&O compounds.

The second highest number of complaints were for taste and odour (49 complaints), which can be generated by one or more factors including but not limited to the presence of BGA, soluble organics, elevated chlorine residual, etc. Algal blooms can result in the presence of taste and odour compounds such as Geosmin and MIB. Reduced water consumption and extended retention times during low flows in the reticulation system 'long age' and dead ends may also contribute to imparting taste and odour to the water. The highest complaint was from Kerang, which received 29 complaints due to elevated MIB in the treated water.

LMW received seven alleged illness complaints during the reporting period. The alleged illness complaints were thoroughly investigated and were found not related to the quality of water supplied

Tables 7A and 7B show a comparison between the number of water quality complaints received during 2023/24, to those of the previous year, and the types of complaints received by each of LMW's water sampling locality respectively.

Table 7C shows the types of water quality complaints, total water quality complaints received during 2023/24, and the number of complaints per 100 customers supplied.

**TABLE 7A – Types of complaints compared to previous reporting periods**

Type of Complaints	Number of Complaints	Comparison with previous reporting periods			Comments
	23/24	22/23	21/22		
<b>Colour</b>	62	52	14	An increase by ten complaints	
<b>Taste and odour</b>	49	19	9	An increase by thirty complaints	Increase in customer complaints can be attributed to the taste and odour in the treated water at Kerang.
<b>Blue water</b>	0	0	0	No Change	No complaints received.
<b>Alleged sickness</b>	7	3	2	An increase by four complaints	The alleged sickness complaints were investigated thoroughly and found not to be attributed to the quality of the water supplied.
<b>Other</b>	10	5	1	An increase by five complaints	
<b>Total</b>	128	79	26	An increase by forty-nine complaints	

**TABLE 7B – Types of complaints by water sampling locality**

Water sampling locality	Type of complaints					
	Colour	Taste and odour	Blue water	Alleged sickness	Other	Total complaints
<b>Irymple</b>	7	0	0	1	2	10
<b>Kerang</b>	14	29	0	0	0	43
<b>Koondrook</b>	0	0	0	0	0	0
<b>Lake Boga</b>	0	1	0	0	0	1
<b>Merbein</b>	3	2	0	1	1	7
<b>Mildura</b>	37	8	0	3	4	52
<b>Murrabit</b>	0	0	0	0	0	0
<b>Nyah</b>	0	0	0	0	0	0
<b>Nyah West</b>	0	0	0	0	0	0
<b>Piangil</b>	0	1	0	0	0	1
<b>Red Cliffs</b>	0	2	0	1	1	4
<b>Robinvale</b>	0	0	0	0	0	0
<b>Swan Hill</b>	1	6	0	1	1	9
<b>Woorinen</b>	0	0	0	0	1	1
<b>Total</b>	62	49	0	7	10	128

**TABLE 7C – Water Quality Complaints**

TYPE of complaints	No. of complaints	No. of complaints per 100 customers supplied	LMW's Corporate Target
Colour	62	0.081	
Taste and odour	49	0.064	
Alleged sickness	7	0.009	
Blue water	0	0.000	
Other	10	0.013	
<b>Total</b>	<b>128</b>	<b>0.166</b>	<b>&lt; 25 Complaints</b>

## Risk management plan audit results

### Audit Process

During the reporting period, LMW were not required to undertake an external audit of its risk management plan pursuant to the Act. In response to the following eighteen opportunities for improvements (OFI's) identified in the previous Safe Drinking Water Act audit conducted for the period 01 January 2021 to 31 December 2022 inclusive. LMW have undertaken necessary actions to address the OFI as per below:

**TABLE 8 – Status of 2021-2022 Risk Management Plan OFIs**

Opportunity for Improvement	Lower Murray Water Response	Status
<b>Red Cliffs Water Supply System</b>		
A printout of the instrument and calibration and operation manual was observed at the plant, dated September 2016 and may not be the latest version or relate to the current instruments at the plant. There may be a more up to date one available on the LMW Intranet. If so, it is recommended that it be printed out and saved in the folder in the lab at the plant. If not, it is recommended that the manual be reviewed and updated with the latest instruments if necessary.	A new copy was printed and displayed at site and outdated copy disposed of.	Complete
<b>Koondrook WTP and supply system</b>		
The current jar testing equipment at the plant is not fully functional. The team uses the jar testing equipment regularly, especially during rapid changes in water quality.  It is recommended that the plant be provided with an operational jar tester.	A new jar tester arrived shortly after the audit.	Complete
At times the backwash water flowrate exceeds the capacity of the overflow pipework that allows these flows to be diverted to sewer.  It is recommended that the system design be reviewed, and consideration given to installing a larger diameter overflow pipe from the backwash recovery tank	All viable options are being considered	Due by June 2025
<b>Murrabit WTP and supply system</b>		
It is recommended that LMW consider ways to enclose the sedimentation area, to prevent bird droppings from birds roosting in the roof above. Coagulation is one of the	This OFI is a part of Minor Capital Works. Material has been procured to cover the	Due by June 2025



pathogen treatment barriers and compromising this barrier could pose a risk to water quality.	shed with green cloth and waiting for the install	
There are 4 treated water storages at this site, however only 3 are shown on the SCADA. It is recommended that the SCADA be updated to match the plant configuration.	SCADA page has been updated to reflect the actual plant configuration in September 2024.	Completed
<b>Millewa WQP and supply system</b>		
Update required documentation to reflect actual practice once a final decision is made regarding the type of chlorine that will be dosed on an ongoing basis at the plant (that is continue with sodium hypochlorite after the current trial is evaluated, or resume chlorine gas dosing). This could include updating procedures, process descriptions, plans, SCADA, pipework labelling, etc	The sodium Hypochlorite trial is underway. Documentation will be revised once trial is completed.	Due by March 2025
The procedure for adjusting coagulant dose rates that was available at the plant was 10 years old. There may be a more up to date one available on the LMW Intranet. If so, it is recommended that it be printed out and saved in the folder in the lab at the plant. If not, it is recommended that the procedure be reviewed and updated if necessary.	Automation of coagulant dosing is underway.	Due by June 2025
Consider undertaking annual audits rather than biennial. The face-to-face interactions with LMW are important to reinforce the messages that are in the pamphlets and signage.	The annual audit frequency is being considered	Due by June 2025
<b>OFIs relevant more broadly and/or for one system</b>		
<p>Each system has a control limit summary table and then detailed CCP response tables. It is recommended that the following clarifications be made to the terminology used in the CCP tables. For example:</p> <p>(a) In some cases, the limits relate to treated water and transfer water, however within the CCP limit table, these locations are sometimes referred to as "Corrected Water" and "Trim" (e.g. Murrabit CCP5-pH and CCP-FCR). These are likely understood by the operators familiar with these sites. However, it would be beneficial to have consistent terminology to avoid any confusion.</p> <p>(b) For Murrabit CCP6 (Chlorination control) – the second line in the TARGET heading should be "treated" not "transfer"</p> <p>(c) For Koondrook CCP 2 (filtration and UV disinfection) – last dot point in the target column should be "alum", not "caustic"</p> <p>(d) Consider adding to CCP Control Limit summary page first column for PAC what is to be monitored (BGA potentially toxic species) and the units (mm<sup>3</sup>/L) and remove the units from column 2 to be consistent with the layout for other CCPs</p>	<p>Recommendation (a) will not be adopted due to the documents aligning with SCADA systems. The terminology is chosen by the contractor at the time of SCADA commissioning of the site and would cause even more confusion to change it.</p> <p>The recommendations (b)-(f) are being included in the current CCP document revision.</p>	Due by December 2024

<p>(e) Consider including the CCP number in the first column of the Control Limits Summary sheet</p> <p>(f) For Red Cliffs Control Limits Summary sheet add a footnote to the table with an explanation of note 1</p>		
<p>It is recommended that LMW trial an on-line UVT instrument and if successful, implement SCADA calculations and alarms in line with the CCP limits and response protocols.</p>	<p>Quotes were obtained for UVT instruments, but further progress was hindered by staff turnover.</p>	<p>Due by June 2025</p>
<p>Some procedures were observed during the audit that had not been reviewed and updated for a number of years and in some cases greater than 5 years. It is understood that the Records team are in the process of developing reporting tools so that the team are made aware of what documents are due for review. It is recommended that once the Records team sets up this system, the documents that require review be prioritised and updated</p>	<p>Procedures revision is in progress</p>	<p>Due by May 2025</p>
<p>The team advised that there are sites that were not part of the audit scope where the chemical storage volumes could be increased (e.g. 7th Street) and this would be worthwhile to assess what would be required and the associated costs, land availability requirements, etc given there is less certainty in supply than previously</p>	<p>The quotation process has begun as part of major capex, with the view to increase chemical storage capacity at Mildura WTP</p>	<p>Due by March 2025</p>
<p>Murrabit and Koondrook WTPs include the provision of “filter to waste” in their design. The LMW team advised that this facility is not available at Mildura, Kerang and Red Cliffs WTPs. It would be beneficial to incorporate this functionality at these plants. It is recommended that LMW assess the options, costs and practicality of implementing “filter to waste” at these plants</p>	<p>Filter to Waste has been budgeted and scheduled for Red Cliffs under the current Master Capital Works Program for Red Cliffs. Mildura is scheduled for 2028/29.</p>	<p>This is a major project; possible timeframe will be Sep 2026 for Red Cliffs and 2028/29 for Mildura</p>
<p>LMW is implementing a new system to visualise Health Based Target (HBT) compliance (KDX Vantage) that utilises data from SCADA. It is recommended that LMW investigate a data management solution for other operational information organise and collected by the team including external laboratory data, internal laboratory data, instrument calibration records, field inspection records, prepare regular reports. This system would reduce the likelihood of errors, be more efficient than the current process of manually managing data and preparing reports, have the ability to promptly identify non-compliances, etc</p>	<p>Currently an internal Database is under use. A data management solution is being considered as part of the Business BTP</p>	<p>Due by June 2025</p>
<p>There would also be benefit in providing training to a broader team at LMW (e. g. staff who receive calls from the community, network operations and maintenance team members, etc) on the ADWG covering much of the content in the National Water Training Package Unit of Competency - GEN017 - - Apply the risk management principles of the water industry standards, guidelines and legislation and this is recommended for LMW consider.</p>	<p>Planning is underway to develop training packages specific to the AWDG. All viable options are being considered.</p>	<p>Due by June 2025</p>
<p>Consider whether it would be worthwhile having a specific line item in the EMP – Table 3.3.4 Recognition Table – Determining the Level of Event/Response to cover water quality (e.g. what level of incident corresponds to issuing a boil water notice) to assist with determining the level of response required</p>	<p>This OFI is being incorporated into a larger EMP revision.</p>	<p>Due by Dec 2024</p>

<p>It would be more efficient and effective to have an internal process engineering resource to assist the operations and maintenance team, especially during and after flood/blackwater events. They would be able to implement actions raised and lessons learned from these events so that the team is better prepared with more robust processes to more effectively manage future events. Additionally, there is a significant number of equipment and other plant faults identified by the team, and the team could benefit from this additional process engineering resource. This resource could support with root cause analysis and continuous improvement work, resulting in reduced the risk of water quality incidents and make the water supply systems more robust.</p>	<p>A change to LMW Operating model has brought Treatment Operations and Water Quality under the same Manager - Manager Water Quality &amp; Environment. This has improved decision making about plant faults, process changes and will incorporate lessons learnt from past water quality issues into a common review process. A new resource (chemical engineer) has also been employed to validate and streamline decision making in the water quality team. Improvement in the planning processes, regular inspections along with Lessons Learnt are expected to reduce the risk of water quality incidents</p>	<p>Completed</p>
<p>The water quality team is responsible for ensuring that the necessary systems and processes are in place to provide safe drinking water. It is recommended that LMW consider providing an additional resource in this team. The role would assist with progressing a number of the OFI's identified in this audit, provide water quality data review support and backup, help to keep documentation up to date, provide mentoring and refresher training for field teams, conduct internal audits, provide a backup for sampling, etc.</p>	<p>An additional resource has been added to the Water Quality Team Structure. A Trade Waste and Backflow Operator is expected to review water quality data, provide support and fill the current gaps in data, training and general duties. Recruitment has been initiated.</p>	<p>Due by October 2025</p>

# Regulated water

## What is Regulated Water?

Section 6 of the Act allows the Minister for Health to declare any water that is not drinking water, but that may be supplied to the public in circumstances in which it may be mistaken as being drinking water, to be 'regulated water' for the purposes of the Act.

Following consultation between the DH and LMW, the Minister for Health declared the water supplied by LMW to the Millewa and Mystic Park water supply systems as regulated water under Section 6 of the Act.

The declaration for the Millewa system was gazetted in the Victoria Government Gazette Special Edition No. S28 on 15 February 2007 and the Mystic Park system was gazetted in the Victoria Government Gazette Special Edition No. S135 on 19 May 2009.

Declaration as regulated water meant that LMW had to prepare and implement risk management plans for the Millewa and Mystic Park water supply systems. This was to minimise the risk that the water as supplied could be mistaken for drinking water.

LMW take all necessary steps to ensure that residents and visitors to Meringur, Werrimull, Cullulleraine in the Millewa Waterworks District and Mystic Park are aware that the mains water supply to these towns is untreated and not suitable for consumption. The following actions are undertaken:

- provide the 'Living with an Untreated Water Supply' brochure and reminder notices to LMW customers who are connected to an untreated water supply including private diverters, advising that untreated water is not suitable for drinking, teeth brushing or food preparation, and that due care should be taken when bathing and showering to avoid swallowing of untreated water.
- supply the 'Living with an Untreated Water Supply' brochure to accommodation facilities as requested to assist in informing guests that their supply is untreated and is not suitable for drinking, teeth brushing, or food preparation and that due care should be taken when bathing and showering to avoid swallowing of untreated water bathing.
- provide 'Do Not Drink' signs free of charge to the responsible managers of all publicly accessible taps connected to untreated water (e.g., parks, public toilets, schools, halls, caravan parks, etc.).
- provide notification via Information Statements of the property's untreated water supply to intending property purchasers.
- provide new irrigation or domestic and stock customers with an information kit including the 'Living with an Untreated Water Supply' brochure.
- make a copy of our customer charter available which details the respective rights and obligations of customers supplied with untreated water.
- Publish this information on our website.

## LMW's Regulated Water Supplies

### Millewa Water Supply System

- A non-potable water system supplies an area which includes the towns of Meringur, Werrimull and Cullulleraine and also the surrounding rural properties in the Millewa district. The water is sourced from Lake Cullulleraine which is filled directly from the Murray River via an earthen channel. The population served by this supply is estimated to be less than 300.
- The water supply system is primarily a domestic and stock water supply to dryland farmers in the Millewa area located to the west of Mildura. Previously, the water from Lake Cullulleraine had been chlorinated as it was pumped into the system to control the nuisance growth of the *Plumatella* species, which if allowed to become established within a pipeline system can cause severe ongoing operational challenges.

- In 2013, LMW commissioned a Water Quality Plant at Lake Cullulleraine. The plant has improved water quality; providing clearer water for domestic uses such as washing, and farmers can benefit as the impact of clogging on their spraying equipment is reduced.
- The treatment plant comprises two large lagoons that alternate as storages for removing turbidity. Aluminium sulphate is used to aid in the precipitation of the suspended matter. Clarified water is chlorinated whilst gravitating into a clear water storage tank from which it is pumped into the Bambill water storage dam or into the Cullulleraine reticulation system.
- The 182 ML storage dam at Bambill is an earthen water storage within the Millewa system, located at Bambill South which supplies operating head for the system when the treated water pumps are not operating.
- The dryland area serviced by the Millewa regulated water supply covers an area of approximately 243,500 hectares. The total number of connections for the supply to the dryland farming properties is 252. Biennial audit of Millewa Regulated Water Supply was completed in June 2024.

### **Mystic Park Water Supply System**

A non-potable water system supplies the small township of Mystic Park which is located to the south of Swan Hill. In May 2008, LMW assumed responsibility for the Mystic Park untreated water supply, previously the responsibility of the Gannawarra Shire Council.

The water is sourced from nearby Kangaroo Lake before being screened and pumped to an earthen dam located within the township. A small amount of coagulant is added as the water enters the dam. This dam provides some detention time assisting in the reduction of turbidity in the water, however no disinfection is provided.

The town population is currently 29 with 12 serviced properties, including a hotel, recreation reserve and cenotaph. Biennial audits for Mystic Park Regulated supplies were completed in June 2024.

# APPENDIX A – Water Quality Tables

All samples were taken from within the reticulation network unless mentioned otherwise.

Tables 1 to 3 contain results reporting against the standards listed in Schedule 2 of the Safe Drinking Water Regulations 2015.

Tables 4 to 38 inclusive, are results reporting against health & aesthetic guidelines set in the Australian Drinking Water Guidelines 2011 (ADWG).

Tables 9 to 20 & 34 to 39 inclusive, are parameters from samples taken from LMW's 9 treatment plants entering the reticulation system, 8 localities in total (Mildura & Mildura West have a combined locality, Mildura). This differs from other parameters, which show 14 localities that are supplied from a total of 9 treatment plants.

Tables 9 to 16 inclusive, which have biannual scheduling, have 3 samples reported for Mildura this FY instead of 4, as Mildura West WTP was offline in the last quarter of reporting period.

Tables 17 to 20 and 35 to 41 inclusive, which have quarterly scheduling, have seven samples reported instead of eight, as Mildura West WTP was offline in the last quarter of reporting period.

Tables 5, 9 to 16, 18, 19, 23, 24, & 27 to 29 & 34 inclusive, do not have averages as the average cannot be calculated from 'less than' data.

## Table 1 Escherichia coli (E. coli)

E. coli is a microbial organism associated with potential contamination of water supplies with faecal material.

Drinking Water Quality Standard: All samples of drinking water collected must contain no Escherichia coli per 100 millilitres of drinking water, with exception of any false positive sample.

Water Sampling Locality	Frequency of Sampling	Number of Samples	Maximum detected (CFU/100mL)	Number of detections and investigations conducted (s.22)	Number of samples where standard was not met (s.18)
Irymple	Weekly	52	0	0	0
Kerang	Weekly	53	0	0	0
Koondrook	Weekly	53	0	0	0
Lake Boga	Weekly	52	0	0	0
Merbein	Weekly	52	0	0	0
Mildura <sup>1</sup>	Weekly	116	0	0	0
Murrabit	Weekly	53	0	0	0
Nyah	Weekly	52	0	0	0
Nyah West	Weekly	52	0	0	0
Piangil	Weekly	52	0	0	0
Red Cliffs	Weekly	52	0	0	0
Robinvale	Weekly	52	0	0	0
Swan Hill <sup>1</sup>	Weekly	80	0	0	0
Woorinen South	Weekly	52	0	0	0

<sup>1</sup> Mildura and Swan Hill had more reticulation samples collected and analysed due to large populations served by these supplies.

## Table 2 Trihalomethanes

Trihalomethanes are by-products of reaction between chlorine disinfectant and organic material present in water. These compounds can pose a threat to public health if present in drinking water in high concentrations over extended periods of time.

Water Quality Standard: Total Trihalomethanes must be less than or equal to 0.25 milligrams per litre of drinking water.

Water Sampling Locality	Frequency of Sampling	Number of Samples	Drinking water quality standard (mg/L)	Maximum (mg/L)	Average (mg/L)	Number of samples where standard was not met (s.18)
Irymple	Monthly	12	0.25	0.09	0.05	0
Kerang	Monthly	12	0.25	0.11	0.04	0
Koondrook	Monthly	12	0.25	0.08	0.05	0
Lake Boga	Monthly	12	0.25	0.14	0.06	0
Merbein	Monthly	12	0.25	0.13	0.07	0
Mildura	Monthly	12	0.25	0.09	0.04	0
Murrabit	Monthly	12	0.25	0.05	0.04	0
Nyah	Monthly	12	0.25	0.19	0.08	0
Nyah West	Monthly	12	0.25	0.17	0.07	0
Piangil	Monthly	12	0.25	0.11	0.05	0
Red Cliffs	Monthly	12	0.25	0.15	0.07	0
Robinvale	Monthly	12	0.25	0.13	0.05	0
Swan Hill	Monthly	12	0.25	0.13	0.04	0
Woorinen South	Monthly	12	0.25	0.15	0.06	0



### Table 3 Turbidity

Turbidity is an indirect indicator for the overall quality of water and may represent fine particles such as clays, minerals or microscopic organisms.

Water Quality Standard: The 95<sup>th</sup> percentile of results for samples in any 12-month period must be less than or equal to 5.0 Nephelometric Turbidity Units (NTU).

Water Sampling Locality	Frequency of Sampling	Number of Samples	Maximum turbidity in a sample (NTU)	Maximum 95 <sup>th</sup> percentile of turbidity results in any 12 months (NTU)	Number of 95 <sup>th</sup> percentile of results in any 12 months above standard (s.18)
Irymple	Weekly	52	1.6	0.3	0
Kerang	Weekly	52	1.0	0.4	0
Koondrook	Weekly	52	0.1	0.1	0
Lake Boga	Weekly	52	0.3	0.1	0
Merbein	Weekly	52	0.4	0.4	0
Mildura	Weekly	52	0.8	0.7	0
Murrabit	Weekly	52	1.5	0.2	0
Nyah	Weekly	52	0.1	0.1	0
Nyah West	Weekly	52	0.8	0.1	0
Piangil	Weekly	52	0.3	0.1	0
Red Cliffs	Weekly	52	0.7	0.4	0
Robinvale	Weekly	52	0.7	0.2	0
Swan Hill	Weekly	52	0.4	0.1	0
Woorinen South	Weekly	51 <sup>1</sup>	0.1	0.1	0

<sup>1</sup> Woorinen South had a weekly reticulation sample missed in last quarter of reporting period as discussed in Table 2 – Missing water quality parameter.

## Table 4 Fluoride

Fluoride is added to the drinking water sampling localities listed below to promote oral health as directed by DH. Fluoride samples are taken monthly in each of the fluoridated water sampling localities. No fluoride data is available for Koondrook, Murrabit and Piangil systems as these systems do not have fluoridation.

Drinking Water Quality Standard: The total concentration of fluoride in drinking water should not exceed 1.5 mg/L.

Compliance: Annual average fluoride level must not exceed 1 milligram per litre and all individual samples must be less than 1.5 milligrams per litre fluoride concentrations under s.5 (3) of Health (Fluoridation) Act 1973.

Water Sampling Locality	Frequency of Sampling	Number of Samples	Drinking water quality standard (mg/L)	Target optimum operating fluoride concentration (mg/L)	Maximum (mg/L)	Average (mg/L)	Number of samples where standard was not met (s.18)
Irymple	Weekly	52	1.5	0.8	0.91	0.78	0
Kerang	Weekly	52	1.5	0.8	0.85	0.69	0
Lake Boga	Weekly	52	1.5	0.8	0.95	0.80	0
Merbein	Weekly	52	1.5	0.8	0.89	0.75	0
Mildura	Weekly	52	1.5	0.8	0.94	0.77	0
Nyah	Weekly	52	1.5	0.8	0.93	0.78	0
Nyah West	Weekly	52	1.5	0.8	0.96	0.79	0
Red Cliffs	Weekly	52	1.5	0.8	0.92	0.75	0
Robinvale	Weekly	52	1.5	0.8	0.96	0.79	0
Swan Hill	Weekly	52	1.5	0.8	1.00	0.78	0
Woorinen South	Weekly	51 <sup>1</sup>	1.5	0.8	0.97	0.80	0

<sup>1</sup> Woorinen South had a weekly reticulation sample missed in last quarter of reporting period as discussed in Table 2 – Missing water quality parameter.

**Table 5 Chloroacetic Acid**

Health Guideline Value (ADWG) 0.15 mg/L

Water Sampling Locality	Frequency of Sampling	Number of Samples	Maximum (mg/L)	Met ADWG guideline value (Yes/No)
Irymple	Monthly	12	<0.005	Yes
Kerang	Monthly	12	<0.005	Yes
Koondrook	Monthly	12	<0.005	Yes
Lake Boga	Monthly	12	<0.005	Yes
Merbein	Monthly	12	<0.005	Yes
Mildura	Monthly	12	<0.005	Yes
Murrabit	Monthly	12	<0.005	Yes
Nyah	Monthly	12	<0.005	Yes
Nyah West	Monthly	12	<0.005	Yes
Piangil	Monthly	12	<0.005	Yes
Red Cliffs	Monthly	12	<0.005	Yes
Robinvale	Monthly	12	<0.005	Yes
Swan Hill	Monthly	12	<0.005	Yes
Woorinen South	Monthly	12	<0.005	Yes

**Table 6 Dichloroacetic Acid**

Health Guideline Value (ADWG) 0.1 mg/L

Water Sampling Locality	Frequency of Sampling	Number of Samples	Maximum (mg/L)	Average (mg/L)	Average change Comparison of past reporting period	Met ADWG guideline value (Yes/No)
Irymple	Monthly	12	0.017	0.008	Decreased	Yes
Kerang	Monthly	12	0.021	0.009	Decreased	Yes
Koondroo	Monthly	12	0.026	0.016	Decreased	Yes
Lake Boga	Monthly	12	0.017	0.010	Decreased	Yes
Merbein	Monthly	12	0.021	0.007	Decreased	Yes
Mildura	Monthly	12	0.019	0.008	Decreased	Yes
Murrabit	Monthly	12	0.015	0.011	Decreased	Yes
Nyah	Monthly	12	0.012	0.004	Decreased	Yes
Nyah West	Monthly	12	0.010	0.004	Decreased	Yes
Piangil	Monthly	12	0.032	0.014	Decreased	Yes
Red Cliffs	Monthly	12	0.029	0.012	Decreased	Yes
Robinvale	Monthly	12	0.023	0.010	Decreased	Yes
Swan Hill	Monthly	12	0.012	0.005	Decreased	Yes
Woorinen South	Monthly	12	0.011	0.003	Decreased	Yes

## Table 7 Trichloroacetic Acid

Health Guideline Value (ADWG) 0.1 mg/L

Water Sampling Locality	Frequency of Sampling	Number of Samples	Maximum (mg/L)	Average (mg/L)	Average change Comparison of past reporting period	Met ADWG guideline value (Yes/No)
Irymple	Monthly	12	0.018	0.007	Decreased	Yes
Kerang	Monthly	12	0.021	0.008	Decreased	Yes
Koondrook	Monthly	12	0.029	0.015	Decreased	Yes
Lake Boga	Monthly	12	0.016	0.008	Decreased	Yes
Merbein	Monthly	12	0.020	0.010	Decreased	Yes
Mildura	Monthly	12	0.013	0.006	Decreased	Yes
Murrabit	Monthly	12	0.016	0.010	Decreased	Yes
Nyah	Monthly	12	0.018	0.010	Decreased	Yes
Nyah West	Monthly	12	0.016	0.009	Decreased	Yes
Piangil	Monthly	12	0.032	0.014	Decreased	Yes
Red Cliffs	Monthly	12	0.029	0.011	Decreased	Yes
Robinvale	Monthly	12	0.025	0.008	Decreased	Yes
Swan Hill	Monthly	12	0.009	0.004	Decreased	Yes
Woorinen South	Monthly	12	0.011	0.007	Decreased	Yes

## Table 8 Aluminium

Aesthetic Guideline Value (ADWG) 0.2 mg/L (acid soluble)

LMW uses Aluminium Chlorohydrate or Aluminium Sulphate at our water treatment plants as a coagulant. This can result in the presence of acid soluble aluminium within drinking water. Should acid soluble aluminium exceed a concentration of 0.2 mg/L, a white gelatinous precipitate can form within the distribution network causing “milky coloured” water depending on water pH.

Water Sampling Locality	Frequency of Sampling	Number of Samples	Maximum (mg/L)	Average (mg/L)	Average change Comparison of past 2 reporting periods	Met ADWG guideline value (Yes/No)
Irymple	Monthly	12	0.08	0.03	Decreased	Yes
Kerang	Monthly	12	0.03	0.01	Decreased	Yes
Koondrook	Monthly	12	0.04	0.02	Decreased	Yes
Lake Boga	Monthly	12	0.02	0.01	Decreased	Yes
Merbein	Monthly	12	0.04	0.02	Decreased	Yes
Mildura	Monthly	12	0.18	0.04	Decreased	Yes
Murrabit	Monthly	12	0.07	0.02	Decreased	Yes
Nyah	Monthly	12	0.01	0.01	Decreased	Yes
Nyah West	Monthly	12	0.01	0.01	Decreased	Yes
Piangil	Monthly	12	0.03	0.02	Decreased	Yes
Red Cliffs	Monthly	12	0.04	0.02	Increased	Yes
Robinvale	Monthly	12	0.06	0.02	Increased	Yes
Swan Hill	Monthly	12	0.02	0.01	Decreased	Yes
Woorinen South	Monthly	12	0.02	0.01	Decreased	Yes

## Table 9 2,4 Dichlorophenoxy acetic acid

Health Guideline Value (ADWG) 0.03 mg/L

Water Sampling Locality	Frequency of Sampling	Number of Samples	Maximum (mg/L)	Met ADWG guideline value (Yes/No)
Kerang	6 Monthly	2	<0.01	Yes
Koondrook	6 Monthly	2	<0.01	Yes
Mildura	6 Monthly	3	<0.01	Yes
Murrabit	6 Monthly	2	<0.01	Yes
Piangil	6 Monthly	2	<0.01	Yes
Red Cliffs	6 Monthly	2	<0.01	Yes
Robinvale	6 Monthly	2	<0.01	Yes
Swan Hill	6 Monthly	2	<0.01	Yes

**Table 10 Benzene**

Health Guideline Value (ADWG) 0.001 mg/L

Water Sampling Locality	Frequency of Sampling	Number of Samples	Maximum (mg/L)	Met ADWG guideline value (Yes/No)
<b>Kerang</b>	6 Monthly	2	<0.001	Yes
<b>Koondrook</b>	6 Monthly	2	<0.001	Yes
<b>Mildura</b>	6 Monthly	3	<0.001	Yes
<b>Murrabit</b>	6 Monthly	2	<0.001	Yes
<b>Piangil</b>	6 Monthly	2	<0.001	Yes
<b>Red Cliffs</b>	6 Monthly	2	<0.001	Yes
<b>Robinvale</b>	6 Monthly	2	<0.001	Yes
<b>Swan Hill</b>	6 Monthly	2	<0.001	Yes

**Table 11 Carbon Tetrachloride**

Health Guideline Value (ADWG) 0.003 mg/L

Water Sampling Locality	Frequency of Sampling	Number of Samples	Maximum (mg/L)	Met ADWG guideline value (Yes/No)
<b>Kerang</b>	6 Monthly	2	<0.001	Yes
<b>Koondrook</b>	6 Monthly	2	<0.001	Yes
<b>Mildura</b>	6 Monthly	3	<0.001	Yes
<b>Murrabit</b>	6 Monthly	2	<0.001	Yes
<b>Piangil</b>	6 Monthly	2	<0.001	Yes
<b>Red Cliffs</b>	6 Monthly	2	<0.001	Yes
<b>Robinvale</b>	6 Monthly	2	<0.001	Yes
<b>Swan Hill</b>	6 Monthly	2	<0.001	Yes

**Table 12 1,2 Dichloroethane**

Health Guideline Value (ADWG) 0.06 mg/L

Water Sampling Locality	Frequency of Sampling	Number of Samples	Maximum (mg/L)	Met ADWG guideline value (Yes/No)
<b>Kerang</b>	6 Monthly	2	<0.001	Yes
<b>Koondrook</b>	6 Monthly	2	<0.001	Yes
<b>Mildura</b>	6 Monthly	3	<0.001	Yes
<b>Murrabit</b>	6 Monthly	2	<0.001	Yes
<b>Piangil</b>	6 Monthly	2	<0.001	Yes
<b>Red Cliffs</b>	6 Monthly	2	<0.001	Yes
<b>Robinvale</b>	6 Monthly	2	<0.001	Yes
<b>Swan Hill</b>	6 Monthly	2	<0.001	Yes

**Table 13 1,1 Dichloroethene**

Health Guideline Value (ADWG) 0.03 mg/L

Water Sampling Locality	Frequency of Sampling	Number of Samples	Maximum (mg/L)	Met ADWG guideline value (Yes/No)
<b>Kerang</b>	6 Monthly	2	<0.0001	Yes
<b>Koondrook</b>	6 Monthly	2	<0.0001	Yes
<b>Mildura</b>	6 Monthly	3	<0.0001	Yes
<b>Murrabit</b>	6 Monthly	2	<0.0001	Yes
<b>Piangil</b>	6 Monthly	2	<0.0001	Yes
<b>Red Cliffs</b>	6 Monthly	2	<0.0001	Yes
<b>Robinvale</b>	6 Monthly	2	<0.0001	Yes
<b>Swan Hill</b>	6 Monthly	2	<0.0001	Yes

### Table 14 Pentachlorophenol

Health Guideline Value (ADWG) 0.01 mg/L

Water Sampling Locality	Frequency of Sampling	Number of Samples	Maximum (mg/L)	Met ADWG guideline value (Yes/No)
<b>Kerang</b>	6 Monthly	2	<0.001	Yes
<b>Koondrook</b>	6 Monthly	2	<0.001	Yes
<b>Mildura</b>	6 Monthly	3	<0.001	Yes
<b>Murrabit</b>	6 Monthly	2	<0.001	Yes
<b>Piangil</b>	6 Monthly	2	<0.001	Yes
<b>Red Cliffs</b>	6 Monthly	2	<0.001	Yes
<b>Robinvale</b>	6 Monthly	2	<0.001	Yes
<b>Swan Hill</b>	6 Monthly	2	<0.001	Yes

### Table 15 Tetrachloroethene

Health Guideline Value (ADWG) 0.05 mg/L

Water Sampling Locality	Frequency of Sampling	Number of Samples	Maximum (mg/L)	Met ADWG guideline value (Yes/No)
<b>Kerang</b>	6 Monthly	2	<0.001	Yes
<b>Koondrook</b>	6 Monthly	2	<0.001	Yes
<b>Mildura</b>	6 Monthly	3	<0.001	Yes
<b>Murrabit</b>	6 Monthly	2	<0.001	Yes
<b>Piangil</b>	6 Monthly	2	<0.001	Yes
<b>Red Cliffs</b>	6 Monthly	2	<0.001	Yes
<b>Robinvale</b>	6 Monthly	2	<0.001	Yes
<b>Swan Hill</b>	6 Monthly	2	<0.001	Yes



**Table 16 2,4,6 Trichlorophenol**

Health Guideline Value (ADWG) 0.02 mg/L

Water Sampling Locality	Frequency of Sampling	Number of Samples	Maximum (mg/L)	Met ADWG guideline value (Yes/No)
<b>Kerang</b>	6 Monthly	2	<0.001	Yes
<b>Koondrook</b>	6 Monthly	2	<0.001	Yes
<b>Mildura</b>	6 Monthly	3	<0.001	Yes
<b>Murrabit</b>	6 Monthly	2	<0.001	Yes
<b>Piangil</b>	6 Monthly	2	<0.001	Yes
<b>Red Cliffs</b>	6 Monthly	2	<0.001	Yes
<b>Robinvale</b>	6 Monthly	2	<0.001	Yes
<b>Swan Hill</b>	6 Monthly	2	<0.001	Yes

**Table 17 Sulphate**

Aesthetic Guideline Value (ADWG) 250 mg/L

Samples are taken from water exiting treatment plants.

Water Sampling Locality	Frequency of Sampling	Number of Samples	Maximum (mg/L)	Average (mg/L)	Average change Comparison of past 2 reporting periods	Met ADWG guideline value (Yes/No)
<b>Kerang</b>	3 Monthly	4	99	50	Decreased	Yes
<b>Koondrook</b>	3 Monthly	4	48	26	Decreased	Yes
<b>Mildura</b>	3 Monthly	7	71	46	Increased	Yes
<b>Murrabit</b>	3 Monthly	4	3	2	Decreased	Yes
<b>Piangil</b>	3 Monthly	4	7	3	Increased	Yes
<b>Red Cliffs</b>	3 Monthly	4	66	44	Increased	Yes
<b>Robinvale</b>	3 Monthly	4	52	43	Decreased	Yes
<b>Swan Hill</b>	3 Monthly	4	8	5	Increased	Yes

**Table 18 Arsenic**

Health Guideline Value (ADWG) 0.01 mg/L

Water Sampling Locality	Frequency of Sampling	Number of Samples	Maximum (mg/L)	Met ADWG guideline value (Yes/No)
<b>Kerang</b>	3 Monthly	4	<0.001	Yes
<b>Koondrook</b>	3 Monthly	4	<0.001	Yes
<b>Mildura</b>	3 Monthly	7	<0.001	Yes
<b>Murrabit</b>	3 Monthly	4	<0.001	Yes
<b>Piangil</b>	3 Monthly	4	<0.001	Yes
<b>Red Cliffs</b>	3 Monthly	4	<0.001	Yes
<b>Robinvale</b>	3 Monthly	4	<0.001	Yes
<b>Swan Hill</b>	3 Monthly	4	<0.001	Yes

**Table 19 Selenium**

Health Guideline Value (ADWG) 0.01 mg/L

Water Sampling Locality	Frequency of Sampling	Number of Samples	Maximum (mg/L)	Met ADWG guideline value (Yes/No)
<b>Kerang</b>	3 Monthly	4	<0.001	Yes
<b>Koondrook</b>	3 Monthly	4	<0.001	Yes
<b>Mildura</b>	3 Monthly	7	<0.001	Yes
<b>Murrabit</b>	3 Monthly	4	<0.001	Yes
<b>Piangil</b>	3 Monthly	4	<0.001	Yes
<b>Red Cliffs</b>	3 Monthly	4	<0.001	Yes
<b>Robinvale</b>	3 Monthly	4	<0.001	Yes
<b>Swan Hill</b>	3 Monthly	4	<0.001	Yes

**Table 20 Mercury**

Health Guideline Value (ADWG) 0.001 mg/L

Water Sampling Locality	Frequency of Sampling	Number of Samples	Maximum (mg/L)	Met ADWG guideline value (Yes/No)
<b>Kerang</b>	3 Monthly	4	<0.0001	Yes
<b>Koondrook</b>	3 Monthly	4	<0.0001	Yes
<b>Mildura</b>	3 Monthly	7	<0.0001	Yes
<b>Murrabit</b>	3 Monthly	4	<0.0001	Yes
<b>Piangil</b>	3 Monthly	4	<0.0001	Yes
<b>Red Cliffs</b>	3 Monthly	4	<0.0001	Yes
<b>Robinvale</b>	3 Monthly	4	<0.0001	Yes
<b>Swan Hill</b>	3 Monthly	4	<0.0001	Yes

**Table 21 Gross Alpha Activity<sup>1</sup>**

Health Guideline Value (ADWG) 0.5 Bq/L

Water Sampling Locality	Frequency of Sampling	Number of Samples	Maximum (Bq/L)	Met ADWG guideline value (Yes/No)
<b>Kerang</b>	5 yearly	1	<0.05	Yes
<b>Koondrook</b>	5 yearly	1	<0.05	Yes
<b>Mildura</b>	5 yearly	2	<0.05	Yes
<b>Murrabit</b>	5 yearly	1	<0.05	Yes
<b>Piangil</b>	5 yearly	1	<0.05	Yes
<b>Red Cliffs</b>	5 yearly	1	<0.05	Yes
<b>Robinvale</b>	5 yearly	1	<0.05	Yes
<b>Swan Hill</b>	5 yearly	1	<0.05	Yes

**Table 22 Gross Beta Activity<sup>1</sup>**

Health Guideline Value (ADWG) 0.5 Bq/L

Water Sampling Locality	Frequency of Sampling	Number of Samples	Maximum (Bq/L)	Met ADWG guideline value (Yes/No)
<b>Kerang</b>	5 yearly	1	<0.1	Yes
<b>Koondrook</b>	5 yearly	1	<0.1	Yes
<b>Mildura</b>	5 yearly	2	<0.1	Yes
<b>Murrabit</b>	5 yearly	1	<0.1	Yes
<b>Piangil</b>	5 yearly	1	<0.1	Yes
<b>Red Cliffs</b>	5 yearly	1	<0.1	Yes
<b>Robinvale</b>	5 yearly	1	<0.1	Yes
<b>Swan Hill</b>	5 yearly	1	<0.1	Yes

<sup>1</sup>. Reported results are from 2020 as samples are taken every 5 years from source water for radioactivity monitoring.

**Table 23 Lead**

Health Guideline Value (ADWG) 0.01 mg/L

Water Sampling Locality	Frequency of Sampling	Number of Samples	Maximum (mg/L)	Met ADWG guideline value (Yes/No)
Irymple	3 Monthly	4	<0.001	Yes
Kerang	3 Monthly	4	<0.001	Yes
Koondrook	3 Monthly	4	<0.001	Yes
Lake Boga	3 Monthly	4	<0.001	Yes
Merbein	3 Monthly	4	<0.001	Yes
Mildura	3 Monthly	4	<0.001	Yes
Murrabit	3 Monthly	4	<0.001	Yes
Nyah	3 Monthly	4	<0.001	Yes
Nyah West	3 Monthly	4	0.001	Yes
Piangil	3 Monthly	4	<0.001	Yes
Red Cliffs	3 Monthly	4	<0.001	Yes
Robinvale	3 Monthly	4	0.002	Yes
Swan Hill	3 Monthly	4	<0.001	Yes
Woorinen South	3 Monthly	4	<0.001	Yes

Note: Maximum values of this parameter remained same in comparison to the previous 2 reporting periods except Merbein and Mildura which saw a decrease.

**Table 24 Nickel**

Health Guideline Value (ADWG) 0.02 mg/L

Water Sampling Locality	Frequency of Sampling	Number of Samples	Maximum (mg/L)	Met ADWG guideline value (Yes/No)
Irymple	3 Monthly	4	0.001	Yes
Kerang	3 Monthly	4	0.001	Yes
Koondrook	3 Monthly	4	<0.001	Yes
Lake Boga	3 Monthly	4	<0.001	Yes
Merbein	3 Monthly	4	<0.001	Yes
Mildura	3 Monthly	4	0.001	Yes
Murrabit	3 Monthly	4	<0.001	Yes
Nyah	3 Monthly	4	<0.001	Yes
Nyah West	3 Monthly	4	<0.001	Yes
Piangil	3 Monthly	4	<0.001	Yes
Red Cliffs	3 Monthly	4	<0.001	Yes
Robinvale	3 Monthly	4	<0.001	Yes
Swan Hill	3 Monthly	4	<0.001	Yes
Woorinen South	3 Monthly	4	<0.001	Yes

Note: The maximum values of this parameter have remained same in comparison to the previous 2 reporting periods for Irymple, Kerang and Mildura, Nyah, Nyah West, Red Cliffs and decreased for Koondrook, Lake Boga, Merbein, Murrabit, Piangil, Robinvale, Swan Hill and Woorinen.

**Table 25 Zinc**

Aesthetic Guideline Value (ADWG) 3 mg/L

Water Sampling Locality	Frequency of Sampling	Number of Samples	Maximum (mg/L)	Average (mg/L)	Average change Comparison of past 2 reporting periods	Met ADWG guideline value (Yes/No)
Irymple	3 Monthly	4	0.008	0.005	Decreased	Yes
Kerang	3 Monthly	4	0.019	0.011	Increased	Yes
Koondrook	3 Monthly	4	0.008	0.005	Decreased	Yes
Lake Boga	3 Monthly	4	0.003	0.002	Decreased	Yes
Merbein	3 Monthly	4	0.009	0.008	Increased	Yes
Mildura	3 Monthly	4	0.019	0.008	Increased	Yes
Murrabit	3 Monthly	4	0.016	0.009	Increased	Yes
Nyah	3 Monthly	4	0.014	0.009	Increased	Yes
Nyah West	3 Monthly	4	0.018	0.012	Decreased	Yes
Piangil	3 Monthly	4	0.014	0.008	Increased	Yes
Red Cliffs	3 Monthly	4	0.021	0.014	Decreased	Yes
Robinvale	3 Monthly	4	0.038	0.019	Increased	Yes
Swan Hill	3 Monthly	4	0.011	0.005	Decreased	Yes
Woorinen South	3 Monthly	4	0.014	0.010	Decreased	Yes

**Table 26 Nitrate (as Nitrogen)**Health Guideline Value 11.29 mg N/L<sup>1</sup>

Water Sampling Locality	Frequency of Sampling	Number of Samples	Maximum (mg N/L)	Average (mg N/L)	Average change Comparison of past 2 reporting periods	Met ADWG guideline value (Yes/No)
Irymple	3 Monthly	4	0.14	0.05	Decrease	Yes
Kerang	3 Monthly	4	0.21	0.10	Decrease	Yes
Koondrook	3 Monthly	4	0.10	0.05	Decrease	Yes
Lake Boga	3 Monthly	4	0.12	0.06	Increased	Yes
Merbein	3 Monthly	4	0.17	0.09	Increased	Yes
Mildura	3 Monthly	4	0.13	0.06	Increased	Yes
Murrabit	3 Monthly	4	0.13	0.06	Decrease	Yes
Nyah	3 Monthly	4	0.25	0.10	Increased	Yes
Nyah West	3 Monthly	4	0.22	0.09	Increased	Yes
Piangil	3 Monthly	4	0.15	0.08	Increased	Yes
Red Cliffs	3 Monthly	4	0.14	0.06	Increased	Yes
Robinvale	3 Monthly	4	0.12	0.06	Increased	Yes
Swan Hill	3 Monthly	4	0.09	0.05	Decrease	Yes
Woorinen South	3 Monthly	4	0.21	0.09	Increased	Yes

<sup>1</sup> Calculated for Nitrate as Nitrogen from ADWG health-based guideline value of 50 mg/L for Nitrate as Nitrate.

**Table 27 Cyanide**

Health Guideline Value (ADWG) 0.08 mg/L

Water Sampling Locality	Frequency of Sampling	Number of Samples	Maximum (mg/L)	Met ADWG guideline value (Yes/No)
Irymple	3 Monthly	4	<0.005	Yes
Kerang	3 Monthly	4	<0.005	Yes
Koondrook	3 Monthly	4	<0.005	Yes
Lake Boga	3 Monthly	4	<0.005	Yes
Merbein	3 Monthly	4	<0.005	Yes
Mildura	3 Monthly	4	<0.005	Yes
Murrabit	3 Monthly	4	<0.005	Yes
Nyah	3 Monthly	4	<0.005	Yes
Nyah West	3 Monthly	4	<0.005	Yes
Piangil	3 Monthly	4	<0.005	Yes
Red Cliffs	3 Monthly	4	<0.005	Yes
Robinvale	3 Monthly	4	<0.005	Yes
Swan Hill	3 Monthly	4	<0.005	Yes
Woorinen South	3 Monthly	4	<0.005	Yes

Note: The min/max values of this parameter have remained the same in comparison to the previous 2 reporting periods, except for Nyah, Nyah West, Piangil and Robinvale which saw a decrease.

**Table 28 Chromium**

Health Guideline Value (ADWG) 0.05 mg/L

Water Sampling Locality	Frequency of Sampling	Number of Samples	Maximum (mg/L)	Met ADWG guideline value (Yes/No)
Irymple	3 Monthly	4	<0.001	Yes
Kerang	3 Monthly	4	<0.001	Yes
Koondrook	3 Monthly	4	<0.001	Yes
Lake Boga	3 Monthly	4	<0.001	Yes
Merbein	3 Monthly	4	<0.001	Yes
Mildura	3 Monthly	4	<0.001	Yes
Murrabit	3 Monthly	4	<0.001	Yes
Nyah	3 Monthly	4	<0.001	Yes
Nyah West	3 Monthly	4	<0.001	Yes
Piangil	3 Monthly	4	<0.001	Yes
Red Cliffs	3 Monthly	4	<0.001	Yes
Robinvale	3 Monthly	4	<0.001	Yes
Swan Hill	3 Monthly	4	<0.001	Yes
Woorinen South	3 Monthly	4	0.006	Yes

Note: Max values of this parameter have Remained the same in comparison to the previous 2 reporting periods except for Woorinen South which saw an increase.

**Table 29 Cadmium**

Health Guideline Value (ADWG) 0.002 mg/L

Water Sampling Locality	Frequency of Sampling	Number of Samples	Maximum (mg/L)	Met ADWG guideline value (Yes/No)
Irymple	3 Monthly	4	<0.0002	Yes
Kerang	3 Monthly	4	<0.0002	Yes
Koondrook	3 Monthly	4	<0.0002	Yes
Lake Boga	3 Monthly	4	<0.0002	Yes
Merbein	3 Monthly	4	<0.0002	Yes
Mildura	3 Monthly	4	<0.0002	Yes
Murrabit	3 Monthly	4	<0.0002	Yes
Nyah	3 Monthly	4	<0.0002	Yes
Nyah West	3 Monthly	4	<0.0002	Yes
Piangil	3 Monthly	4	<0.0002	Yes
Red Cliffs	3 Monthly	4	<0.0002	Yes
Robinvale	3 Monthly	4	<0.0002	Yes
Swan Hill	3 Monthly	4	<0.0002	Yes
Woorinen South	3 Monthly	4	<0.0002	Yes

Note: The min/max values of this parameter have Remained the same in comparison to the previous 2 reporting periods.

**Table 30 Copper**

Water Quality Standard: Total concentration of copper in drinking water should not exceed 2.0 mg/L.

Water Sampling Locality	Frequency of Sampling	Number of Samples	Drinking water quality standard (mg/L)	Maximum (mg/L)	Average (mg/L)	Average change Comparison of past 2 reporting periods	Number of samples where standard was not met (s. 18)
Irymple	3 Monthly	4	2	0.004	0.003	Decreased	0
Kerang	3 Monthly	4	2	0.011	0.006	Increased	0
Koondrook	3 Monthly	4	2	0.018	0.013	Decreased	0
Lake Boga	3 Monthly	4	2	0.025	0.009	Decreased	0
Merbein	3 Monthly	4	2	0.011	0.009	Decreased	0
Mildura	3 Monthly	4	2	0.008	0.004	Decreased	0
Murrabit	3 Monthly	4	2	0.015	0.011	Increased	0
Nyah	3 Monthly	4	2	0.074	0.027	Increased	0
Nyah West	3 Monthly	4	2	0.060	0.038	Decreased	0
Piangil	3 Monthly	4	2	0.064	0.040	Increased	0
Red Cliffs	3 Monthly	4	2	0.014	0.009	Increased	0
Robinvale	3 Monthly	4	2	0.038	0.022	Increased	0
Swan Hill	3 Monthly	4	2	0.020	0.013	Increased	0
Woorinen South	3 Monthly	4	2	0.019	0.009	No change	0

**Table 31 Manganese**

Health Guideline Value (ADWG) 0.5 mg/L

Water Sampling Locality	Frequency of Sampling	Number of Samples	Maximum (mg/L)	Met ADWG guideline value (Yes/No)
Irymple	3 Monthly	4	0.006	Yes
Kerang	3 Monthly	4	0.007	Yes
Koondrook	3 Monthly	4	0.010	Yes
Lake Boga	3 Monthly	4	0.002	Yes
Merbein	3 Monthly	4	0.004	Yes
Mildura	3 Monthly	4	0.004	Yes
Murrabit	3 Monthly	4	<0.001	Yes
Nyah	3 Monthly	4	<0.001	Yes
Nyah West	3 Monthly	4	0.001	Yes
Piangil	3 Monthly	4	<0.001	Yes
Red Cliffs	3 Monthly	4	0.002	Yes
Robinvale	3 Monthly	4	0.033	Yes
Swan Hill	3 Monthly	4	0.001	Yes
Woorinen South	3 Monthly	4	0.008	Yes

**Table 32 pH**

Aesthetic Guideline Range (ADWG) 6.5-8.5 pH

Water Sampling Locality	Frequency of Sampling	Number of Samples	Minimum	Maximum	Average	Average change Comparison of past 2 reporting periods	Aesthetic operating range
Irymple	Weekly	52	7.0	7.7	7.2	Decreased	6.5-8.5
Kerang	Weekly	52	6.8	7.6	7.2	Decreased	6.5-8.5
Koondrook	Weekly	52	6.9	8.4	7.5	Increased	6.5-8.5
Lake Boga	Weekly	52	7.1	7.8	7.5	Decreased	6.5-8.5
Merbein	Weekly	52	6.9	7.5	7.1	Decreased	6.5-8.5
Mildura	Weekly	52	6.9	7.6	7.2	Decreased	6.5-8.5
Murrabit	Weekly	52	6.6	7.5	7.2	Decreased	6.5-8.5
Nyah	Weekly	52	6.8	7.6	7.2	Decreased	6.5-8.5
Nyah West	Weekly	52	6.9	7.6	7.2	Increased	6.5-8.5
Piangil	Weekly	52	6.7	7.7	7.3	Decreased	6.5-8.5
Red Cliffs	Weekly	52	7.1	7.7	7.4	Increased	6.5-8.5
Robinvale	Weekly	52	7.1	7.7	7.3	Decreased	6.5-8.5
Swan Hill	Weekly	52	6.9	7.7	7.3	Increased	6.5-8.5
Woorinen South	Weekly	51 <sup>1</sup>	6.9	7.6	7.3	Decreased	6.5-8.5

<sup>1</sup> Woorinen South had a weekly reticulation sample missed in last quarter of reporting period as discussed in Table 2 – Missing water quality parameter.



**Table 33 Colour**

Aesthetic Guideline Value (ADWG) 15 HU

Water Sampling Locality	Frequency of Sampling	Number of Samples	Maximum Pt/Co Units <sup>1</sup>	Average Pt/Co Units <sup>1</sup>	Average change Comparison of past 2 reporting periods	Met ADWG guideline value (Yes/No)
Irymple	Monthly	12	<2	<2	Decreased	Yes
Kerang	Monthly	12	2	<2	Decreased	Yes
Koondrook	Monthly	12	<2	<2	Decreased	Yes
Lake Boga	Monthly	12	<2	<2	Decreased	Yes
Merbein	Monthly	12	12	<2	Increased	Yes
Mildura	Monthly	12	<2	<2	Decreased	Yes
Murrabit	Monthly	12	<2	<2	Decreased	Yes
Nyah	Monthly	12	<2	<2	Decreased	Yes
Nyah West	Monthly	12	<2	<2	Decreased	Yes
Piangil	Monthly	12	<2	<2	Decreased	Yes
Red Cliffs	Monthly	12	<2	<2	Decreased	Yes
Robinvale	Monthly	12	<2	<2	Decreased	Yes
Swan Hill	Monthly	12	<2	<2	Decreased	Yes
Woorinen South	Monthly	11 <sup>2</sup>	<2	<2	Decreased	Yes

<sup>1</sup> Pt-Co Units = Hazen Units (HU) = PCU = Platinum Cobalt Colour

<sup>2</sup> Woorinen South had a reticulation sample missed in last quarter of reporting period as discussed in Table 2 – Missing water quality parameter.

**Table 34 Iron**

Aesthetic Guideline Value (ADWG) 0.3 mg/L

Water Sampling Locality	Frequency of Sampling	Number of Samples	Maximum (mg/L)	Met ADWG guideline value (Yes/No)
Irymple	3 Monthly	4	0.03	Yes
Kerang	3 Monthly	4	0.02	Yes
Koondrook	3 Monthly	4	<0.01	Yes
Lake Boga	3 Monthly	4	0.03	Yes
Merbein	3 Monthly	4	0.03	Yes
Mildura	3 Monthly	4	0.02	Yes
Murrabit	3 Monthly	4	0.01	Yes
Nyah	3 Monthly	4	<0.01	Yes
Nyah West	3 Monthly	4	0.02	Yes
Piangil	3 Monthly	4	<0.01	Yes
Red Cliffs	3 Monthly	4	<0.01	Yes
Robinvale	3 Monthly	4	0.02	Yes
Swan Hill	3 Monthly	4	<0.01	Yes
Woorinen South	3 Monthly	4	0.12	Yes

**Table 35 Hardness (as CaCO<sub>3</sub>)**

Aesthetic Guideline Value (ADWG) 200 mg/L

Water Sampling Locality	Frequency of Sampling	Number of Samples	Maximum (mg/L)	Average (mg/L)	Average change Comparison of past 2 reporting periods	Met ADWG guideline value (Yes/No)
Kerang	3 Monthly	4	92	50	Increased	Yes
Koondrook	3 Monthly	4	28	22	Decreased	Yes
Mildura	3 Monthly	7	83	56	Decreased	Yes
Murrabit	3 Monthly	4	28	22	Decreased	Yes
Piangil	3 Monthly	4	57	34	Increased	Yes
Red Cliffs	3 Monthly	4	54	38	Decreased	Yes
Robinvale	3 Monthly	4	55	42	Increased	Yes
Swan Hill	3 Monthly	4	82	42	Increased	Yes

**Table 36 Chloride**

Aesthetic Guideline Value (ADWG) 250 mg/L

Water Sampling Locality	Frequency of Sampling	Number of Samples	Maximum (mg/L)	Average (mg/L)	Average change Comparison of past 2 reporting periods	Met ADWG guideline value (Yes/No)
<b>Kerang</b>	3 Monthly	4	42	21	Increased	Yes
<b>Koondrook</b>	3 Monthly	4	20	13	Decreased	Yes
<b>Mildura</b>	3 Monthly	7	44	31	Decreased	Yes
<b>Murrabit</b>	3 Monthly	4	30	18	Decreased	Yes
<b>Piangil</b>	3 Monthly	4	61	34	Increased	Yes
<b>Red Cliffs</b>	3 Monthly	4	43	31	Decreased	Yes
<b>Robinvale</b>	3 Monthly	4	44	26	Increased	Yes
<b>Swan Hill</b>	3 Monthly	4	87	44	Increased	Yes

**Table 37 Sodium**

Aesthetic Guideline Value (ADWG) 180 mg/L

Water Sampling Locality	Frequency of Sampling	Number of Samples	Maximum (mg/L)	Average (mg/L)	Average change Comparison of past 2 reporting periods	Met ADWG guideline value (Yes/No)
<b>Kerang</b>	3 Monthly	4	32	21	Decreased	Yes
<b>Koondrook</b>	3 Monthly	4	27	20	Decreased	Yes
<b>Mildura</b>	3 Monthly	7	35	21	Decreased	Yes
<b>Murrabit</b>	3 Monthly	4	15	10	Decreased	Yes
<b>Piangil</b>	3 Monthly	4	29	17	Increased	Yes
<b>Red Cliffs</b>	3 Monthly	4	44	29	Increased	Yes
<b>Robinvale</b>	3 Monthly	4	51	33	Decreased	Yes
<b>Swan Hill</b>	3 Monthly	4	48	24	Increased	Yes

### Table 38 Electrical Conductivity

Aesthetic Guideline Value (ADWG) <895  $\mu\text{S}/\text{cm}$ <sup>1</sup>

ADWG has no specific guidelines values for Electrical Conductivity (EC) but specifies an Aesthetic Guideline Value of 600 mg/L for Total Dissolved Solids (TDS). Approximate EC value has been calculated from following correlation between TDS and EC.

$$EC = \frac{TDS}{k}$$

Where  $k$  has been taken as 0.67.

Water Sampling Locality	Frequency of Sampling	Number of Samples	Maximum ( $\mu\text{S}/\text{cm}$ )	Average ( $\mu\text{S}/\text{cm}$ )	Average change Comparison of past 2 reporting periods	Met ADWG guideline value (Yes/No)
Kerang	3 Monthly	4	390	225	Decreased	Yes
Koondrook	3 Monthly	4	220	170	Decreased	Yes
Mildura	3 Monthly	7	330	239	Decreased	Yes
Murrabit	3 Monthly	4	150	109	Decreased	Yes
Piangil	3 Monthly	4	260	165	Increased	Yes
Red Cliffs	3 Monthly	4	330	243	No change	Yes
Robinvale	3 Monthly	4	350	263	Decreased	Yes
Swan Hill	3 Monthly	4	390	210	No change	Yes

<sup>1</sup> Calculated for TDS aesthetic guideline value of 600 mg/L

### Table 39 Calcium

No Guideline Value

Water Sampling Locality	Frequency of Sampling	Number of Samples	Maximum (mg/L)	Average (mg/L)
Kerang	3 Monthly	4	27	13.7
Koondrook	3 Monthly	4	4.7	3.8
Mildura	3 Monthly	7	22	13.9
Murrabit	3 Monthly	4	4.7	3.9
Piangil	3 Monthly	4	9.9	6.0
Red Cliffs	3 Monthly	4	9.5	6.7
Robinvale	3 Monthly	4	9.8	7.7
Swan Hill	3 Monthly	4	13	6.8

**Table 40 Alkalinity (as CaCO<sub>3</sub>)**

No Guideline Value

Water Sampling Locality	Frequency of Sampling	Number of Samples	Maximum (mg/L)	Average (mg/L)	Average change Comparison of past 2 reporting periods
<b>Kerang</b>	3 Monthly	4	34	25	Decreased
<b>Koondrook</b>	3 Monthly	4	22	19	Decreased
<b>Mildura</b>	3 Monthly	7	30	23	Decreased
<b>Murrabit</b>	3 Monthly	4	28	22	Decreased
<b>Piangil</b>	3 Monthly	4	32	24	Decreased
<b>Red Cliffs</b>	3 Monthly	4	27	22	Decreased
<b>Robinvale</b>	3 Monthly	4	52	42	Decreased
<b>Swan Hill</b>	3 Monthly	4	45	29	Decreased

**Table 41 Magnesium**

No Guideline Value

Water Sampling Locality	Frequency of Sampling	Number of Samples	Maximum (mg/L)	Average (mg/L)	Average change Comparison of past 2 reporting periods
<b>Kerang</b>	3 Monthly	4	5.9	4.0	Decreased
<b>Koondrook</b>	3 Monthly	4	3.9	3.0	Decreased
<b>Mildura</b>	3 Monthly	7	7.0	5.1	Decreased
<b>Murrabit</b>	3 Monthly	4	4.0	3.0	Decreased
<b>Piangil</b>	3 Monthly	4	7.9	4.6	Increased
<b>Red Cliffs</b>	3 Monthly	4	7.5	5.2	Decreased
<b>Robinvale</b>	3 Monthly	4	7.4	5.4	Increased
<b>Swan Hill</b>	3 Monthly	4	12	6.1	Increased